

- 1- Two-years and commissioning spare parts list will be finalized by owner.
Meeting Conclusion (2024/09/14): It was decided that the vendor would send the agreed 2 years spare parts list to ZAFIC.
- 2- Vendor needs to confirm that there is no deviation on table of scope of supply that is attached to PIDEDEC MR, section 2.3, otherwise, vendor deviation shall be clearly specified.
Meeting Conclusion (2024/09/14): It was decided that ZAFIC would send MR Package with last revision of attachment.
- 3- As per agreement between the owner and vendor, No bearing RTD is considered for compressor bearings, Also there is no vibration sensor on compressor casing.

Meeting Conclusion (2024/09/14): It was agreed that there is no need to consider RTD and Vibration sensor for compressor casing.

But it was agreed that vendor to consider RTD for motor as follows:

One RTD for each bearing (2 RTDs for bearings) and 6 RTDs for windings (2 RTDs per phase) .

- 4- Regarding scope of inspection, as per owner agreements, vendor ITP will be followed for compressors, for other items, PIDEDEC scope of inspection will be followed by vendor.

Meeting Conclusion (2024/09/14): It was agreed that, vendor ITP will be followed for compressors skids, for other items, PIDEDEC scope of inspection will be followed by vendor.

- 5- Owner / vendor shall clarify for the possibility of using non-standard flanges inside the refrigeration package. If applicable, mating flanges with bolts, nuts, and gaskets for non-standard flanges shall be provided by vendor.

Meeting Conclusion (2024/09/14): NO deviation.

- 6- Regarding the MTO for insulation inside the refrigeration package, final decision will be specified by owner after its coordination with the vendor, please note that as per PIDEDEC MR, MTO shall be provided by vendor.

Meeting Conclusion (2024/09/14): NO deviation.

General Items

Meeting Conclusion (2024/09/14): All items noted and no deviation.

Electrical Items

- 1- About test & inspection of all electrical items as per our SOI (vendor's ITP)

Meeting Conclusion (2024/09/14): It was agreed that, ZAFIC would send SOI to MY COM for review.

- 2- About EX type of MV motors which is "EX ec IIC T3" in vendor's documents

Meeting Conclusion (2024/09/14): Noted. (MY COM has confirmed that "EX ec- IIC- T3" is suitable for EX type of MV motors.)

- 3- About Spare parts for electrical equipment (motors, LCP,..) that we didn't find any specific item.

Meeting Conclusion (2024/09/14): Noted