

 <p>شرکت توسعه صنایع لوان Lavan Industry Development Company</p>	<p>LIDCO, Pars SEE Zone, Assaluyeh, Integrated Methanol and Ammonia Plant 3000 MTPD MeOH / 900 MTPD NH3 PROJECT</p>																				
	<p>I/O List</p>																				
<p>Document No. 17735-06</p>		<p>Page</p>																			
<table border="1"> <tr> <th>Project No.</th> <td>N278</td> </tr> </table>	Project No.	N278	<table border="1"> <tr> <th>Vendor Doc.</th> <td>VD</td> </tr> </table>	Vendor Doc.	VD	<table border="1"> <tr> <th>P.O. No.</th> <td>6019</td> </tr> </table>	P.O. No.	6019	<table border="1"> <tr> <th>Department</th> <td>IN</td> </tr> </table>	Department	IN	<table border="1"> <tr> <th>Document Type</th> <td>LIS</td> </tr> </table>	Document Type	LIS	<table border="1"> <tr> <th>Serial No</th> <td>0006</td> </tr> </table>	Serial No	0006	<table border="1"> <tr> <th>Revision</th> <td>07</td> </tr> </table>	Revision	07	<p>Page 1 of 3</p>
Project No.	N278																				
Vendor Doc.	VD																				
P.O. No.	6019																				
Department	IN																				
Document Type	LIS																				
Serial No	0006																				
Revision	07																				

**Airpack B.V. - Air Compressor –
Integrated Methanol and Ammonia Plant
17735-COM I/O List (K020)**

07	30-05-2024	Issued for Approval	S.K.	S.K.	J.J.
06	21-05-2024	Issued for Approval	S.K.	S.K.	J.J.
05	14-04-2024	Issued for Approval	A.Z.	S.K.	J.J.
04	05-04-2024	Issued for Approval	A.Z.	S.K.	J.J.
03	22-02-2024	Issued for Approval	A.Z.	S.K.	J.J.
02	02-02-2024	Issued for Approval	T.T.	S.K.	J.J.
01	10-11-2023	Issued for Approval	T.T.	S.K.	J.J.
REV.	DATE	DESCRIPTION	DRAWN	CHECKED	APPROVED

This document has been produced by Contractor for LIDCO. It is confidential and cannot be disclosed to or used by any third party for any purpose without prior written consent.

I/O List

Document No. 17735-06

Page

Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No	Revision
N278	VD	6019	IN	LIS	0006	07

Page 2 of 3

LIST OF REVISED PAGES

Rev. Page	01	02	03	04	05	06	07	08	09	10	Rev. Page	01	02	03	04	05	Rev. Page	01	02	03	04	05
1	X	X	X	X	X	X	X				51						76					
2	X	X	X	X	X	X	X				52						77					
3	X	X	X	X	X	X	X				53						78					
4											54						79					
5											55						80					
6											56						81					
7											57						82					
8											58						83					
9											59						84					
10											60						85					
11											61						86					
12											62						87					
13											63						88					
14											64						89					
15											65						90					
16											66						91					
17											67						92					
18											68						ATTACHMENT					
19											69						1					
20											70						2					
21											71						3					
22											72						4					
23											73						5					
24											74						6					
25											75						7					

TAG NUMBER	LINE NUMBER	SERVICE DESCRIPTION	INSTRUMENT TYPE	LOCATION	P&ID NUMBER	SYSTEM TYPE	I/O TYPE	SIGNAL TYPE	CALIBRATED RANGE	ENGINEERING UNIT	STATE 0	STATE 1	SET POINT		SET POINT		FROM	TO	PROTOCOL	IS/NIS	NO/NC	DCS/ESD	REDUNDANCY
													POINT L	POINT H	POINT L	POINT H							
320PT-8201	1"-IA-320-01-D42-N	Pressure transmitter package inlet	TRANSMITTER	FIELD	N-278-VD-6019-PR-PID-0002	COMPRESSOR	AI	4-20 mA	0..16 (bar(g))	-	-	-	7.5	12			IDAN-820	DCS	HART	NIS	-	DCS	REDUNDANT
320TT-8201	1"-IA-320-01-D42-N	Temperature transmitter package inlet	TRANSMITTER	FIELD	N-278-VD-6019-PR-PID-0002	COMPRESSOR	AI	4-20 mA	0..100°C	-	-	-	40	50			IDAN-820	DCS	HART	NIS	-	DCS	-
320TT-8202	3/4"-IA-320-05-F42-H	Temperature transmitter 1st stage discharge	TRANSMITTER	FIELD	N-278-VD-6019-PR-PID-0002	COMPRESSOR	AI	4-20 mA	0..250°C	-	-	-	145	185			IDAN-820	DCS	HART	NIS	-	DCS	-
320PT-8202	3/4"-IA-320-05-F42-H	Pressure transmitter 2nd stage suction	TRANSMITTER	FIELD	N-278-VD-6019-PR-PID-0002	COMPRESSOR	AI	4-20 mA	0..60 (bar(g))	-	-	-	19	15.5			IDAN-820	DCS	HART	NIS	-	DCS	REDUNDANT
320TT-8203	3/4"-IA-320-05-F42-H	Temperature transmitter 2nd stage suction	TRANSMITTER	FIELD	N-278-VD-6019-PR-PID-0002	COMPRESSOR	AI	4-20 mA	0..250°C	-	-	-		65	70		IDAN-820	DCS	HART	NIS	-	DCS	REDUNDANT
320TT-8204	3/4"-IA-320-06-F42-H	Temperature transmitter 2nd stage discharge	TRANSMITTER	FIELD	N-278-VD-6019-PR-PID-0002	COMPRESSOR	AI	4-20 mA	0..160°C	-	-	-	105	125			IDAN-820	DCS	HART	NIS	-	DCS	-
320TT-8205	4"-IA-320-08-D42-N	Temperature transmitter package outlet	TRANSMITTER	FIELD	N-278-VD-6019-PR-PID-0002	COMPRESSOR	AI	4-20 mA	0..160°C	-	-	-					IDAN-820	DCS	HART	NIS	-	DCS	-
320PT-8203	3/4"-IA-320-09-D42-N	Pressure transmitter package outlet	TRANSMITTER	FIELD	N-278-VD-6019-PR-PID-0002	COMPRESSOR	AI	4-20 mA	0..60 (bar(g))	-	-	-	25		34		IDAN-820	DCS	HART	NIS	-	DCS	REDUNDANT
320PT-8204	Oil system	Pressure transmitter oil system	TRANSMITTER	FIELD	N-278-VD-6019-PR-PID-0002	COMPRESSOR	AI	4-20 mA	-1..5 (bar(g))	-	-	-					IDAN-820	DCS	HART	NIS	-	DCS	-
320PCV-8201	3/4"-IA-320-11-D42-N	Pressure Control Valve Bypass	CONTROL VALVE	FIELD	N-278-VD-6019-PR-PID-0002	COMPRESSOR	AO	4-20 mA	NA/NA	-	-	-					DCS	IDAN-820	-	NIS	-	DCS	REDUNDANT
320XL-8201	-	Running Light	SIGNAL	FIELD	N-278-VD-6019-PR-PID-0002	DCS	DO	24 VDC	NA/NA	Stopped	Running	-	-	-	-	-	DCS	300LP-820	-	-	-	DCS	-
320XL-8202	-	Operational Light	SIGNAL	FIELD	N-278-VD-6019-PR-PID-0002	DCS	DO	24 VDC	NA/NA	Operational	Operational	-	-	-	-	-	DCS	300LP-820	-	-	-	DCS	-
320XL-8203	-	Fault Light	SIGNAL	FIELD	N-278-VD-6019-PR-PID-0002	DCS	DO	24 VDC	NA/NA	Healthy	Fault	-	-	-	-	-	DCS	300LP-820	-	-	-	DCS	-
320XL-8204	-	Emergency Trip Light	SIGNAL	FIELD	N-278-VD-6019-PR-PID-0002	DCS	DO	24 VDC	NA/NA	Healthy	Eme trip	-	-	-	-	-	DCS	300LP-820	-	-	-	DCS	-
320HS-8201	-	Start Pushbutton	SIGNAL	FIELD	N-278-VD-6019-PR-PID-0002	DCS	DI	VOLT FREE	NA/NA	Start	-	-	-	-	-	-	300LP-820	DCS	-	-	-	NO	DCS
320HS-8202	-	Stop Pushbutton	SIGNAL	FIELD	N-278-VD-6019-PR-PID-0002	DCS	DI	VOLT FREE	NA/NA	Stop	-	-	-	-	-	-	300LP-820	DCS	-	-	-	NC	DCS
320HS-8203	-	Emergency Stop Pushbutton	SIGNAL	FIELD	N-278-VD-6019-PR-PID-0002	DCS	DI	VOLT FREE	NA/NA	ESD	Healthy	-	-	-	-	-	300LP-820	DCS	-	-	-	NC	DCS
320HS-8204	-	Local / Remote Switch	SIGNAL	FIELD	N-278-VD-6019-PR-PID-0002	DCS	DI	VOLT FREE	NA/NA	Local	Remote	-	-	-	-	-	300LP-820	DCS	-	-	-	NO	DCS
320PZLC-8201	3/4"-IA-320-11-D42-N	Pressure Control Valve Bypass Positioner	POSITIONER	FIELD	N-278-VD-6019-PR-PID-0002	COMPRESSOR	AI	4-20 mA	0..100%	-	-	-					IDAN-820	DCS	HART	NIS	-	DCS	-