

	LIDCO, Pars SEE Zone, Assaluyeh, Integrated Methanol and Ammonia Plant 3000 MTPD MeOH / 900 MTPD NH3 PROJECT						
	I/O List						
	Document No. 17735-06						Page
	Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No	Revision
N278	VD	6019	IN	LIS	0006	06	Page 1 of 3

**Airpack B.V. - Air Compressor –
Integrated Methanol and Ammonia Plant
17735-COM I/O List (K020)**

Code 2
M.Dalakeh

06	21-05-2024	Issued for Approval	S.K.	S.K.	J.J.
05	14-04-2024	Issued for Approval	A.Z.	S.K.	J.J.
04	05-04-2024	Issued for Approval	A.Z.	S.K.	J.J.
03	22-02-2024	Issued for Approval	A.Z.	S.K.	J.J.
02	02-02-2024	Issued for Approval	T.T.	S.K.	J.J.
01	10-11-2023	Issued for Approval	T.T.	S.K.	J.J.
REV.	DATE	DESCRIPTION	DRAWN	CHECKED	APPROVED

This document has been produced by Contractor for LIDCO. It is confidential and cannot be disclosed to or used by any third party for any purpose without prior written consent.

I/O List

Document No. 17735-06

Page

Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No	Revision
N278	VD	6019	IN	LIS	0006	06

Page 2 of 3

LIST OF REVISED PAGES

Rev. Page	01	02	03	04	05	06	07	08	09	10	Rev. Page	01	02	03	04	05	Rev. Page	01	02	03	04	05
1	X	X	X	X	X	X					51						76					
2	X	X	X	X	X	X					52						77					
3	X	X	X	X	X	X					53						78					
4											54						79					
5											55						80					
6											56						81					
7											57						82					
8											58						83					
9											59						84					
10											60						85					
11											61						86					
12											62						87					
13											63						88					
14											64						89					
15											65						90					
16											66						91					
17											67						92					
18											68						ATTACHMENT					
19											69						1					
20											70						2					
21											71						3					
22											72						4					
23											73						5					
24											74						6					
25											75						7					

TAG NUMBER	LINE NUMBER	SERVICE DESCRIPTION	I/O	SIGNAL	CALIBRATED	ENGINEERING	STATE 0	STATE 1	SET POINT		SET POINT		FROM	TO	PROTOCOL	IS/NIS	NO/NC	DCS/ESD	REDUNDANCY		
									POINT L	POINT H	POINT L	POINT H									
320PT-8201	1"-IA-320-01-D42-N	Pressure transmitter package inlet	TRANSMITTER	FIELD	N-278-VD-6019-PR-PID-0002	COMPRESSOR	AI	4-20 mA	0..16 (bar(g))	-	-	7.5	12	IDAN-820	DCS	HART	NIS	-	DCS	REDUNDANT	
320TT-8201	1"-IA-320-01-D42-N	Temperature transmitter package inlet	TRANSMITTER	FIELD	N-278-VD-6019-PR-PID-0002	COMPRESSOR	AI	4-20 mA	0..100°C	-	-	40	50	IDAN-820	DCS	HART	NIS	-	DCS	-	
320TT-8203	3/4"-IA-320-05-F42-H	Temperature transmitter 1st stage	TRANSMITTER	FIELD	N-278-VD-6019-PR-PID-0002	COMPRESSOR	AI	4-20 mA	0..250°C	-	-	145	185	IDAN-820	DCS	HART	NIS	-	DCS	-	
320PT-8202	3/4"-IA-320-05-F42-H	Pressure transmitter 2nd stage sud	TRANSMITTER	FIELD	N-278-VD-6019-PR-PID-0002	COMPRESSOR	AI	4-20 mA	0..60 (bar(g))	-	-	19	15.5	IDAN-820	DCS	HART	NIS	-	DCS	REDUNDANT	
320TT-8203	3/4"-IA-320-05-F42-H	Temperature transmitter 2nd stage	TRANSMITTER	FIELD	N-278-VD-6019-PR-PID-0002	COMPRESSOR	AI	4-20 mA	0..250°C	-	-	-	65	70	IDAN-820	DCS	HART	NIS	-	DCS	REDUNDANT
320TT-8204	3/4"-IA-320-06-F42-H	Temperature transmitter 2nd stage discharge	TRANSMITTER	FIELD	N-278-VD-6019-PR-PID-0002	COMPRESSOR	AI	4-20 mA	0..160°C	-	-	-	105	125	IDAN-820	DCS	HART	NIS	-	DCS	-
320TT-8205	1"-IA-320-08-D42-N	Temperature transmitter package outlet	TRANSMITTER	FIELD	N-278-VD-6019-PR-PID-0002	COMPRESSOR	AI	4-20 mA	0..160°C	-	-	-	-	-	IDAN-820	DCS	HART	NIS	-	DCS	-
320PT-8203	3/4"-IA-320-09-D42-N	Pressure transmitter oil system	TRANSMITTER	FIELD	N-278-VD-6019-PR-PID-0002	COMPRESSOR	AI	4-20 mA	0..60 (bar(g))	-	-	-	25	34	IDAN-820	DCS	HART	NIS	-	DCS	REDUNDANT
320PT-8204	Oil system	Pressure transmitter oil system	TRANSMITTER	FIELD	N-278-VD-6019-PR-PID-0002	COMPRESSOR	AI	4-20 mA	-1..5 (bar(g))	-	-	-	-	-	IDAN-820	DCS	HART	NIS	-	DCS	-
320PCV-8201	3/4"-IA-320-11-D42-N	Pressure Control Valve Bypass	CONTROL VALVE	FIELD	N-278-VD-6019-PR-PID-0002	COMPRESSOR	AI	4-20 mA	NA/NA	-	-	-	-	-	DCS	IDAN-820	-	NIS	-	DCS	REDUNDANT
320AL-8201	-	Running Light	SIGNAL	FIELD	N-278-VD-6019-PR-PID-0002	DCS	DO	24 VDC	NA/NA	Stopped	Running	-	-	-	DCS	300LP-820	-	-	-	DCS	-
320AL-8202	-	Operational Light	SIGNAL	FIELD	N-278-VD-6019-PR-PID-0002	DCS	DO	24 VDC	NA/NA	Operational	-	-	-	-	DCS	300LP-820	-	-	-	DCS	-
320AL-8203	-	Fault Light	SIGNAL	FIELD	N-278-VD-6019-PR-PID-0002	DCS	DO	24 VDC	NA/NA	Healthy	Fault	-	-	-	DCS	300LP-820	-	-	-	DCS	-
320AL-8204	-	Emergency Trip Light	SIGNAL	FIELD	N-278-VD-6019-PR-PID-0002	DCS	DO	24 VDC	NA/NA	Healthy	Eme trip	-	-	-	DCS	300LP-820	-	-	-	DCS	-
320HS-8201	-	Start Pushbutton	SIGNAL	FIELD	N-278-VD-6019-PR-PID-0002	DCS	DI	VOLT FREE	NA/NA	Start	-	-	-	-	300LP-820	DCS	-	-	-	NO	DCS
320HS-8202	-	Stop Pushbutton	SIGNAL	FIELD	N-278-VD-6019-PR-PID-0002	DCS	DI	VOLT FREE	NA/NA	Stop	-	-	-	-	300LP-820	DCS	-	-	-	NC	DCS
320HS-8203	-	Emergency Stop Pushbutton	SIGNAL	FIELD	N-278-VD-6019-PR-PID-0002	DCS	DI	VOLT FREE	NA/NA	ESD	Healthy	-	-	-	300LP-820	DCS	-	-	-	NC	DCS
320HS-8204	-	Local / Remote Switch	SIGNAL	FIELD	N-278-VD-6019-PR-PID-0002	DCS	DI	VOLT FREE	NA/NA	Local	Remote	-	-	-	300LP-820	DCS	-	-	-	NO	DCS
320PZLC-8201	3/4"-IA-320-11-D42-N	Pressure Control Valve Bypass Positioner	POSITIONER	FIELD	N-278-VD-6019-PR-PID-0002	COMPRESSOR	AI	4-20 mA	0-100%NA	-	-	-	-	-	IDAN-820	DCS	HART	NIS	-	DCS	-

(Comment on rev 03 PID and rcs per spec of project.) All dash "-" should be removed.

Should be AI