



LIDCO, Pars SEE Zone, Assaluyeh,
Integrated Methanol and Ammonia
Plant 3000 MTPD MeOH / 900 MTPD NH3 PROJECT



Index of Vendor Data Book

Document No. 17735-19

Page

Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No	Revision	Page
N278	VD	6019	GN	LIS	0020	02	Page 1 of 5

**Airpack B.V. - Air Compressor –
Integrated Methanol and Ammonia Plant
17735-COM Index of Vendor Data Book (K020)**

REV.	DATE	DESCRIPTION	DRAWN	CHECKED	APPROVED
02	19-12-2023	Issued for Approval	M.C.	J.J.	
01	13-11-2023	Issued for Approval	M.C.	J.J.	

NARGAN COMPANY	
INSPECTION	
1- APPROVED	<input type="checkbox"/>
2- APPROVED AND NOTED	<input checked="" type="checkbox"/>
3- NOT APPROVED	<input type="checkbox"/>
BY: M. REZAEI	DATE: 19 Dec 2023
Signature: <i>[Handwritten Signature]</i>	

This document has been produced by Contractor for LIDCO. It is confidential and cannot be disclosed to or used by any third party for any purpose without prior written consent.

Index of Vendor Data Book

Document No. 17735-19

Page

Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No	Revision	Page
N278	VD	6019	GN	LIS	0020	02	Page 2 of 5

LIST OF REVISED PAGES

Rev. Page	01	02	03	04	05	Rev. Page	01	02	03	04	05	Rev. Page	01	02	03	04	05	Rev. Page	01	02	03	04	05	
1	X	X				26						51						76						
2	X	X				27						52						77						
3	X	X				28						53						78						
4	X	X				29						54						79						
5		X				30						55						80						
6						31						56						81						
7						32						57						82						
8						33						58						83						
9						34						59						84						
10						35						60						85						
11						36						61						86						
12						37						62						87						
13						38						63						88						
14						39						64						89						
15						40						65						90						
16						41						66						91						
17						42						67						92						
18						43						68						ATTACHMENT						
19						44						69						1						
20						45						70						2						
21						46						71						3						
22						47						72						4						
23						48						73						5						
24						49						74						6						
25						50						75						7						

NARGAN COMPANY	
INSPECTION	
APPROVED	<input type="checkbox"/>
APPROVED AS NOTED	<input checked="" type="checkbox"/>
NOT APPROVED	<input type="checkbox"/>
BY: M. REZAEI	DATE: 23 Dec 2023
SIGN:	



Each book shall have page numbers.


Integrated Methanol and Ammonia Plant

Book 1; Purchase order data

- A. UNPRICED PO
- B. MATERIAL REQUISITION
- C. FINAL TECHNICAL CLARIFICATIONS WITH PURCHASER
- D. ENGINEERING QUERIES
- E. CONCESSION REQUEST

(N278-000-ME-
MR-1020-001)
Rev.02

	NARGAN COMPANY
INSPECTION	
APPROVED	<input type="checkbox"/>
APPROVED AS NOTED	<input checked="" type="checkbox"/>
NOT APPROVED	<input type="checkbox"/>
BY: M. REZAEI DATE: 23 Dec 2023	
SIGN: 	

	Vendor doc. Number 17735-19	P.O. NO.: LIDCO-PO-NEC-278-6019
	Vendor: Airpack Nederland B.V.	

VDB Part II (Operating and Maintenance Data) has been missed here. It shall contains:

- Final Issue of all vendor documents according to approved VPIS by purchaser in PCIM
- AFC As-Built Drawings/Vendor Prints
- Installation Instruction
- Pre-commissioning, Operating Manual and Maintenance Data
- Spare parts data including the exploded views and spare parts numbers.
- All documents shall its own number as per approved VPIS and with final revision numbers.

Book 3, Inspection and quality control documents

A. SKID

1. Material Certificates
2. NDT certificates
3. Paint report
4. Welding

B. PIPING

1. Material Certificates
2. NDT Certificates
3. Hydrostatic test certificates
4. Paint report
5. Welding

Material summary list and

C. COMPRESSOR

1. Material Certificates
2. Hydrostatic test certificates

D. LV MOTOR

1. Routine test certificate

E. COOLERS

1. Material Certificates
2. Hydrostatic test certificates
3. NDT Certificates

Material summary list and

F. PULSATION DAMPERS

1. Material Certificates
2. Hydrostatic test certificates
3. NDT Certificates

Material summary list and



Vendor doc. Number

17735-19

Vendor:

Airpack Nederland B.V.

P.O. NO.:

LIDCO-PO-NEC-278-6019

INSPECTION	
APPROVED	<input type="checkbox"/>
APPROVED AS NOTED	<input checked="" type="checkbox"/>
NOT APPROVED	<input type="checkbox"/>
BY: M. REZAEI DATE: 23 Dec 2023	
SIGN:	

Integrated Methanol and Ammonia Plant

Book 3, Inspection and quality control documents

F. INSTRUMENTATION AND VALVES (calibration / Material / etc.)



1. Pressure Gauge
2. Pressure transmitter
3. Temperature Transmitter
4. Thermowell + Element
5. Temperature gauge
6. Pressure Safety Valve
7. Hand Ball Valve
8. Pressure Control Valve
9. Check Valve
10. Y-Strainer
11. Junction box

For pressure safety and pressure control valves as per approved ITP, required documents shall be added here.

J. GENERAL

1. Weight data sheet
2. Certificate of compliance
3. Noise test certificate
4. Included spare parts
5. Functional / performance test results
6. Signed quality test & inspection plan
7. Release note

Signed packing list and

 NARGAN COMPANY	
INSPECTION	
APPROVED	<input type="checkbox"/>
APPROVED AS NOTED	<input checked="" type="checkbox"/>
NOT APPROVED	<input type="checkbox"/>
BY: M. REZAEI DATE: 23 Dec 2023	
SIGN: 	



Vendor doc. Number

17735-19

P.O. NO.:

LIDCO-PO-NEC-278-6019

Vendor:

Airpack Nederland B.V.