

	<b>LIDCO, Pars SEE Zone, Assaluyeh, Integrated Methanol and Ammonia Plant 3000 MTPD MeOH / 900 MTPD NH3 PROJECT</b>						
	<b>Instrument Cable schedule</b>						
	Document No. 17735-52						Page
	Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No	Revision
	N278	VD	6019	IN	SCH	0044	06
							Page 1 of 3

**Airpack B.V. - Air Compressor –  
Integrated Methanol and Ammonia Plant  
17735-COM Instrument Cable schedule (K020)**

Sorry for inconvenience  
 There was a discrepancy between Nargan Elec. and CNI Dpt. understanding of control philosophy  
 Please implement our minor comment on page No. 3

Code 2  
 M.Dalakeh

06	08-05-2024	Issued for Approval	R.T.	S.K.	J.J.
05	02-05-2024	Issued for Approval	R.T.	S.K.	J.J.
04	03-04-2024	Issued for Approval	R.T.	S.K.	J.J.
03	20-03-2024	Issued for Approval	R.T.	S.K.	J.J.
02	15-02-2024	Issued for Approval	A.Z.	S.K.	J.J.
01	13-12-2023	Issued for Approval	A.Z.	S.K.	J.J.
<b>REV.</b>	<b>DATE</b>	<b>DESCRIPTION</b>	<b>DRAWN</b>	<b>CHECKED</b>	<b>APPROVED</b>

This document has been produced by Contractor for LIDCO. It is confidential and cannot be disclosed to or used by any third party for any purpose without prior written consent.

Instrument Cable schedule

Document No. 17735-52

Page

Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No	Revision	Page
N278	VD	6019	IN	SCH	0044	06	Page 2 of 3

LIST OF REVISED PAGES

Rev. Page	01	02	03	04	05	06	07	08	09	10	Rev. Page	01	02	03	04	05	Rev. Page	01	02	03	04	05
1	X	X	X	X	X	X					51						76					
2	X	X	X	X	X	X					52						77					
3	X	X	X	X	X	X					53						78					
4											54						79					
5											55						80					
6											56						81					
7											57						82					
8											58						83					
9											59						84					
10											60						85					
11											61						86					
12											62						87					
13											63						88					
14											64						89					
15											65						90					
16											66						91					
17											67						92					
18											68						ATTACHMENT					
19											69						1					
20											70						2					
21											71						3					
22											72						4					
23											73						5					
24											74						6					
25											75						7					

SI	LOCATION	FROM BOARD / INSTRUMENT	GLAND	CABLE NAME	TO BOARD / INSTRUMENT	TERM . STRIP	TERMINAL	GLAND	LOCATION	CABLE	CABLE LENGTH	CABLE CODE	FUNCTION	SCOPE
			SIZE					SIZE		mm <sup>2</sup>	m			
1	300LP-820													
2	FIELD	DCS	TBA	300CDDN820	300LP-820	300TDD820	1-14	M25	FIELD	14Cx1,5	TBA	14C1.501ARGYN	GENERATOR MULTIPAIR CABLE PUSHBUTTONS FROM CUSTOMER	CUSTOMER
3	FIELD	DCS	TBA	300CDDN821	300LP-820	300TDD820	15-28	M25	FIELD	14Cx1,5	TBA	14C1.501ARGYN	GENERATOR MULTIPAIR CABLE LAMPS FROM CUSTOMER	CUSTOMER
4	FIELD	DCS	TBA	320CED820	300LP-820	300TED820	1-4	M20	FIELD	4Cx1,5	TBA	4C1.501ASRDN	GENERATOR MULTIPAIR CABLE ESD BUTTON FROM CUSTOMER	CUSTOMER
5	300IDAN-820													
6	FIELD	DCS	TBA	320CDDN820	300IDAN-820	300TDA820 300TDA821	1-48 1-10	M40	FIELD	19x2x0,75	TBA	19P0.7511ARGYN	GENERATOR MULTIPAIR CABLE TRANSMITTER FROM CUSTOMER	CUSTOMER
7	FIELD	320PT-8201	M20	320PT-8201	300IDAN-820	300TDA820	1-3	M20	FIELD	1Px1,5	7	1P1.501ARGYN	PACKAGE INLET PRESSURE TRANSMITTER	AIRPACK
8	FIELD	320PT-8202	M20	320PT-8202	300IDAN-820	300TDA820	4-6	M20	FIELD	1Px1,5	7	1P1.501ARGYN	2ND STAGE SUCTION PRESSURE TRANSMITTER	AIRPACK
9	FIELD	320PT-8203	M20	320PT-8203	300IDAN-820	300TDA820	7-9	M20	FIELD	1Px1,5	7	1P1.501ARGYN	PACKAGE OUTLET PRESSURE TRANSMITTER	AIRPACK
10	FIELD	320PT-8204	M20	320PT-8204	300IDAN-820	300TDA820	10-12	M20	FIELD	1Px1,5	7	1P1.501ARGYN	OIL SYSTEM PRESSURE TRANSMITTER	AIRPACK
11	FIELD	320TT-8201	M20	320TT-8201	300IDAN-820	300TDA820	13-15	M20	FIELD	1Px1,5	7	1P1.501ARGYN	PACKAGE INLET TEMPERATURE TRANSMITTER	AIRPACK
12	FIELD	320TF-8202	M20	320TF-8202	300IDAN-820	300TDA820	16-18	M20	FIELD	1Px1,5	7	1P1.501ARGYN	1ST STAGE DISCHARGE PRESSURE TRANSMITTER	AIRPACK
13	FIELD	320TT-8203	M20	320TT-8203	300IDAN-820	300TDA820	19-21	M20	FIELD	1Px1,5	7	1P1.501ARGYN	2ND STAGE SUCTION TEMPERATURE TRANSMITTER	AIRPACK
14	FIELD	320TT-8204	M20	320TT-8204	300IDAN-820	300TDA820	22-24	M20	FIELD	1Px1,5	7	1P1.501ARGYN	2ND STAGE DISCHARGE TEMPERATURE TRANSMITTER	AIRPACK
15	FIELD	320TF-8205	M20	320TF-8205	300IDAN-820	300TDA820	25-27	M20	FIELD	1Px1,5	7	1P1.501ARGYN	PACKAGE OUTLET TEMPERATURE TRANSMITTER	AIRPACK
16	FIELD	320PZC-8201	M20	320PZC-8201	300IDAN-820	300TDA820	28-30	M20	FIELD	1Px1,5	7	1P1.501ARGYN	PRESSURE CONTROL VALVE POSITION FEEDBACK	AIRPACK
17	FIELD	320PCV-8201	M20	320PCV-8201	300IDAN-820	300TDA821	1-3	M20	FIELD	1Px1,5	7	1P1.501ARGYN	PRESSURE CONTROL VALVE	AIRPACK