



LIDCO, Pars SEE Zone, Assaluyeh,
Integrated Methanol and Ammonia
Plant 3000 MTPD MeOH / 900 MTPD NH3 PROJECT



Line List

Document No. 17735-61

Page

Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No	Revision	Page
N278	VD	6019	IN	LIS	0048	03	Page 1 of 3

**Airpack B.V. - Air Compressor –
Integrated Methanol and Ammonia Plant
17735-COM Line List (K020)**

code-2
M. Vakili

REV.	DATE	DESCRIPTION	DRAWN	CHECKED	APPROVED
03	23-01-2024	Issued for Approval	T.T.	S.K.	J.J.
02	08-01-2024	Issued for Approval	S.K.	S.K.	J.J.
01	19-12-2023	Issued for Approval	S.K.	S.K.	J.J.

This document has been produced by Contractor for LIDCO. It is confidential and cannot be disclosed to or used by any third party for any purpose without prior written consent.

Line List

Document No. 17735-61

Page

Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No	Revision	Page
N278	VD	6019	IN	LIS	0048	03	Page 2 of 3

LIST OF REVISED PAGES

Rev. Page	01	02	03	04	05	Rev. Page	01	02	03	04	05	Rev. Page	01	02	03	04	05	Rev. Page	01	02	03	04	05
1	X	X	X			26						51						76					
2	X	X	X			27						52						77					
3	X	X	X			28						53						78					
4	X					29						54						79					
5						30						55						80					
6						31						56						81					
7						32						57						82					
8						33						58						83					
9						34						59						84					
10						35						60						85					
11						36						61						86					
12						37						62						87					
13						38						63						88					
14						39						64						89					
15						40						65						90					
16						41						66						91					
17						42						67						92					
18						43						68						ATTACHMENT					
19						44						69						1					
20						45						70						2					
21						46						71						3					
22						47						72						4					
23						48						73						5					
24						49						74						6					
25						50						75						7					

Line no.	Line description	P&ID Number	Line size	Schedule	Ends Note 7	Pipe material Note-2	Flange as per ASME B16.5	Flange Material Note-2	Operating press. Max.	Design press.	Operating temp.	Design temp.	Insulation	Tie in Point	Paint system
P&ID for High Pressure Air Compressor K020															
1"-IA-320-01-D42-N	Package inlet	N278-VD-6019-PR-PID-0002	1"	S-40S	BE	SS316L	300#	ASTM A182	9,5 bar(g)	12,5 bar(g)	46°C	75°C	Not Insulated	TP-8201	1
1"-IA-320-02-D42-N	1st stage suction	N278-VD-6019-PR-PID-0002	1"	S-40S	BE	SS316L	300#	ASTM A182	9,5 bar(g)	12,5 bar(g)	46°C	75°C	Not Insulated	N/A	1
3/4"-IA-320-03-F42-H	1st stage discharge	N278-VD-6019-PR-PID-0002	3/4"	S-40S	BE	SS316L	600#	ASTM A182	23,3 bar(g)	30 bar(g)	157°C	175°C	Hot Insulated	N/A	3
3/4"-IA-320-04-F42-H	1st stage discharge	N278-VD-6019-PR-PID-0002	3/4"	S-40S	BE	SS316L	600#	ASTM A182	23,3 bar(g)	30,5 bar(g)	46°C	185°C	Hot Insulated	N/A	3
3/4"-IA-320-05-D42-N	2nd stage suction	N278-VD-6019-PR-PID-0002	3/4"	S-40S	BE	SS316L	300#	ASTM A182	23,3 bar(g)	30,5 bar(g)	157°C	175°C	Not Insulated	N/A	3
3/4"-IA-320-06-F42-H	2nd stage discharge	N278-VD-6019-PR-PID-0002	3/4"	S-40S	BE	SS316L	600#	ASTM A182	22,1 bar(g)	39 bar(g)	60°C	175°C	Hot Insulated	N/A	3
3/4"-IA-320-07-F42-H	2nd stage discharge	N278-VD-6019-PR-PID-0002	3/4"	S-40S	BE	SS316L	600#	ASTM A182	30 bar(g)	39 bar(g)	60°C	175°C	Hot Insulated	N/A	3
4"-IA-320-08-D42-N	Package outlet	N278-VD-6019-PR-PID-0002	4"	S-40S	BE	SS316L	300#	ASTM A182	30 bar(g)	39 bar(g)	60°C	75°C	Not Insulated	N/A	1
3/4"-IA-320-09-D42-N	Package outlet	N278-VD-6019-PR-PID-0002	3/4"	S-40S	BE	SS316L	300#	ASTM A182	30 bar(g)	39 bar(g)	60°C	75°C	Not Insulated	N/A	1
3/4"-IA-320-10-D42-N	Package outlet	N278-VD-6019-PR-PID-0002	3/4"	S-40S	BE	SS316L	300#	ASTM A182	30 bar(g)	39 bar(g)	60°C	75°C	Not Insulated	TP-8202	1
3/4"-IA-320-11-D42-N	Bypass	N278-VD-6019-PR-PID-0002	3/4"	S-40S	BE	SS316L	300#	ASTM A182	31 bar(g)	40 bar(g)	60°C	75°C	Not Insulated	N/A	1
P&ID for High Pressure Air Compressor K020 water system															
3/4"-CWS-320-20-B24C-N	Cooling water inlet	N278-VD-6019-PR-PID-0002	3/4"	S-40S	BE	CS	150#	ASTM A 105	4,5 bar(g)	7 bar(g)	36°C	75°C	Not Insulated	TP-8203	1
3/4"-CWS-320-21-B24C-N	Cooling water inlet	N278-VD-6019-PR-PID-0002	3/4"	S-40S	BE	CS	150#	ASTM A 105	4,5 bar(g)	7 bar(g)	36°C	75°C	Not Insulated	N/A	1
4"-CWR-320-22-B24C-N	Cooling water outlet	N278-VD-6019-PR-PID-0002	4"	S-10S	BE	CS	150#	ASTM A 105	5 bar(g)	7 bar(g)	46°C	75°C	Not Insulated	N/A	1
3/4"-CWS-320-23-B24C-N	Cooling water inlet	N278-VD-6019-PR-PID-0002	3/4"	S-40S	BE	CS	150#	ASTM A 105	4,5 bar(g)	7 bar(g)	36°C	75°C	Not Insulated	N/A	1
4"-CWR-320-24-B24C-N	Cooling water outlet	N278-VD-6019-PR-PID-0002	4"	S-10S	BE	CS	150#	ASTM A 105	5 bar(g)	7 bar(g)	46°C	75°C	Not Insulated	N/A	1
3/4"-CWR-320-25-B24C-N	Cooling water outlet	N278-VD-6019-PR-PID-0002	3/4"	S-40S	BE	CS	150#	ASTM A 105	5 bar(g)	7 bar(g)	46°C	75°C	Not Insulated	N/A	1
3/4"-CWR-320-26-B24C-N	Cooling water outlet	N278-VD-6019-PR-PID-0002	3/4"	S-40S	BE	CS	150#	ASTM A 105	5 bar(g)	7 bar(g)	46°C	75°C	Not Insulated	TP-8204	1

Notes:

- 1.) pipe class will be followed for all component mentioned like, tem NPS, Rating, Schedule, Type, Specification Notes, NIPPLES ,FITTINGS - threaded & Butt Welded ,Caps, elbows, Tees ,Couplings ,Plug, Unions, Swaged Nipples, Boss, Blinds , spectacle blinds, GASKETS, bolts / Fasteners , valves, etc.
- 2.) All Components in water system are CS material and will externally painted (except for the valves which will be carbon steel and externally painted)
- 3.) Corrosion allowance = 0 mm. Corrosion allowance watersystem= 3,2mm
- 4.) Design code = ASME B31.3
- 5.) Stress Relieving = Not applicable
- 6.) Welding Spec : N278-000-PI-JSS-1300-009
- 7.) BE = Beveled Ends (for pipe)
- 8.) Valve body material with ASTM A105 shall be supplied in Normalized condition

below items shall be added to line list:

1. paint code
2. NDT
3. test pressure
4. test media