



LIDCO, Pars SEE Zone, Assaluyeh,  
Integrated Methanol and Ammonia  
Plant 3000 MTPD MeOH / 900 MTPD NH3 PROJECT



Pulsation Study Approach 1 Calculations

Document No. 17735-24

Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No	Revision	Page
N278	VD	6019	ME	CAL	0026	03	Page 1 of 10

## Pulsation Study Approach 1 Calculations

Code 2  
M.Dalakeh

REV.	DATE	DESCRIPTION	DRAWN	CHECKED	APPROVED
03	20-06-2024	Issued for Information	S.K.	J.J.	S.K.
02	13-12-2023	Issued for Information	S.K.	J.J.	S.K.
01	14-09-2023	Issued for Information	S.K.	J.J.	S.K.

This document has been produced by Contractor for LIDCO. It is confidential and cannot be disclosed to or used by any third party for any purpose without prior written consent.

Pulsation Study Approach 1 Calculations

Document No. 17735-24

Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No	Revision	Page
N278	VD	6019	ME	CAL	0026	03	Page 2 of 10

LIST OF REVISED PAGES

Rev. Page	01	02	03	04	05	Rev. Page	01	02	03	04	05	Rev. Page	01	02	03	04	05	Rev. Page	01	02	03	04	05
1	X	X				26						51						76					
2	X	X				27						52						77					
3	X	X				28						53						78					
4	X	X				29						54						79					
5	X	X				30						55						80					
6	X	X				31						56						81					
7	X	X				32						57						82					
8	X	X				33						58						83					
9	X	X				34						59						84					
10		X				35						60						85					
11						36						61						86					
12						37						62						87					
13						38						63						88					
14						39						64						89					
15						40						65						90					
16						41						66						91					
17						42						67						92					
18						43						68						ATTACHMENT					
19						44						69						1					
20						45						70						2					
21						46						71						3					
22						47						72						4					
23						48						73						5					
24						49						74						6					
25						50						75						7					



LIDCO, Pars SEE Zone, Assaluyeh,  
Integrated Methanol and Ammonia  
Plant 3000 MTPD MeOH / 900 MTPD NH3 PROJECT



Pulsation Study Approach 1 Calculations

Document No. 17735-24

Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No	Revision	Page
N278	VD	6019	ME	CAL	0026	03	Page 3 of 10

### Design approach 1 in accordance with API 618

Project: Integrated Methanol and Ammonia Plant  
Location: Iran  
Equipment: Air Compressor  
Purchase order: LIDCO-PO-NEC-278-6019  
Airpack reference: 17735-COM

### Requirements

Pulsation levels have to meet the limits as per paragraph 7.9.4.2.5.2.2.1 as well as the criteria in paragraph 7.9.2 through 7.9.3.

#### para 7.9.4.2.5.2.5.1

The peak-to-peak cyclic stress range is far below  $180 \text{ N/mm}^2$ , therefore this paragraph is considered as not applicable.

Pulsation Study Approach 1 Calculations

Document No. 17735-24

Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No	Revision	Page
N278	VD	6019	ME	CAL	0026	03	Page 4 of 10

para 7.9.3.2

$$V_s = 8,1 \cdot PD \cdot \left( \frac{k \cdot T_s}{M} \right)^{1/4}$$

$$V_d = 1,6 \cdot \left( \frac{V_s}{(R)^{1/k}} \right)$$

$$V_s \geq V_d$$

$$V_s \geq 0,03 \text{ m}^3$$

$$V_d \geq 0,03 \text{ m}^3$$

$$\frac{l}{ID} \leq 4.0$$

- $V_s$  = minimum required suction surge volume [m<sup>3</sup>]  
 $V_d$  = minimum required discharge surge volume [m<sup>3</sup>]  
 $K$  = isentropic compression exponent at average operating gas pressure and temperature  
 $T_s$  = absolute suction temperature [K]  
 $M$  = molecular weight  
 $PD$  = total net displaced volume per revolution of all compressor cylinders to be manifolded in the surge volume  
 $R$  = stage pressure ratio at cylinder flanges ( = quotient of absolute discharge and suction pressures)  
 $l$  = surge volume length  
 $ID$  = surge volume inside diameter

Pulsation Study Approach 1 Calculations

Document No. 17735-24

Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No	Revision	Page
N278	VD	6019	ME	CAL	0026	03	Page 5 of 10

para 7.9.4.2.5.2

$$P_{cf} = 3R \%$$

$$P_{cf} \leq 7 \%$$

$P_{cf}$  = maximum allowable unfiltered peak-to-peak pulsation level, as a percentage of average absolute line pressure at the compressor cylinder flange [%]

para 7.9.4.2.5.3.1

$$\Delta p = \frac{1,67 \cdot (R - 1)}{R}$$

$$\Delta p \leq 0,25 \%$$

$\Delta p$  = maximum pressure drop based on steady flow through a pulsation suppression device, as a percentage of the average absolute line pressure at the inlet of the device [%]

$R$  = stage pressure ratio at cylinder flanges ( = quotient of absolute discharge and suction pressures)

para 7.9.2

The gas composition, specified in the purchaser datasheet is considered as the basis of this calculation.

para 7.9.4.2.5.2.2.1

$$P_l = \frac{4,1}{(P_L)^{1/3}}$$

$P_l$  = maximum allowable peak-to-peak pulsation level at any discrete frequency, as a percentage of average absolute pressure [%]

$P_L$  = average absolute line pressure [bar(a)]

Pulsation Study Approach 1 Calculations

Document No. 17735-24

Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No.
N278	VD	6019	ME	CAL	0026

Isentropic exponent is ratio of Cp/Cv and always more than 1. For current project it is approximately equal to 1.4

Input

		stage 1	stage 2	
$K$	isentropic compression exponent	0,9991	0,9982	
$T_s$	abs. suction temperature	313,15	313,15	K
$M$	molecular weight	28,959	28,959	
$PD$	total net displaced volume per revolution	2,259 E-3 [note 1]	8,451 E-4 [note 2]	m <sup>3</sup>
$R$	stage pressure ratio	2,453	1,357	
$P_L$	avg abs. line pressure	17,368	26,250	kg/cm <sup>2</sup> (a)

Compressor stage data

	1 <sup>st</sup> stage	2 <sup>nd</sup> stage	Unit
Suction pressure	9,5	22,1	Bar
Discharge pressure	23,3	30	Bar
Pressure ratio	2,453	1,357	
Suction temperature	313,15	313,15	K

change unit to bar

Please recheck. these values are differ from note 1 and 2.

[note 1]

1<sup>st</sup> stage

stroke 130 mm  
cyl bore 55 mm  
rod dia 30 mm  
Single acting

$$PD = \frac{1}{4} \pi (0,055)^2 \cdot 0,13 = 2,376 \cdot 10^{-3} m^3$$

[note 2]

2<sup>nd</sup> stage

stroke 130 mm  
cyl bore 35 mm  
rod dia 30 mm  
Single acting

$$PD = \frac{1}{4} \pi (0,035)^2 \cdot 0,13 = 9,621 \cdot 10^{-4} m^3$$

Pulsation Study Approach 1 Calculations

Document No. 17735-24

Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No	Revision	Page
N278	VD	6019	ME	CAL	0026	03	Page 7 of 10

Output

para 7.9.3.2

1<sup>st</sup> stage

$$V_s = 8,1 \cdot 2,376 \cdot 10^{-3} \cdot \left( \frac{0,9991 \cdot 313,15}{28,959} \right)^{1/4} = 0,035 \text{ m}^3 = 35 \text{ dm}^3$$

k is approximately  
is equal to 1.4.  
therefore, volume is  
38 dm<sup>3</sup>.

$$V_d = 1,6 \cdot \left( \frac{0,035}{(2,453)^{1/0,9991}} \right) = 0,023 \text{ m}^3 = 23 \text{ dm}^3$$

recalculate based  
on the above  
comment.

Some of the following 3 equations are not true, hence calculated sizes are not acceptable. Sizes are too small for API 618, minimum sizes of 0,03 m<sup>3</sup> must be used.

$$V_s \geq V_d \text{ True}$$

$$V_s \geq 0,03 \text{ m}^3 \text{ True}$$

$$V_d \geq 0,03 \text{ m}^3 \text{ not true! } V_d = 0,023 \text{ m}^3, \text{ according to API 618} \rightarrow V_d$$

k is approximately  
is equal to 1.4.  
therefore, volume is  
38 dm<sup>3</sup>.

2<sup>nd</sup> stage

$$V_s = 8,1 \cdot 9,621 \cdot 10^{-4} \cdot \left( \frac{0,9982 \cdot 313,15}{28,959} \right)^{1/4} = 0,0141 \text{ m}^3 = 14,1 \text{ dm}^3$$

$$V_d = 1,6 \cdot \left( \frac{0,0141}{(1,357)^{1/0,9982}} \right) = 0,0166 \text{ m}^3 = 16,6 \text{ dm}^3$$

Some of the following 3 equations are not true, hence calculated sizes are not acceptable. Sizes are too small for API 618, minimum sizes of 0,03 m<sup>3</sup> must be used.

$$V_s \geq V_d \text{ Not True, so } V_s = 0,03 \text{ m}^3$$

$$V_s \geq 0,03 \text{ m}^3 \text{ Not True, so } V_s = 0,03 \text{ m}^3$$

$$V_d \geq 0,03 \text{ m}^3 \text{ Not True, so } V_d = 0,03 \text{ m}^3$$

Pulsation Study Approach 1 Calculations

Document No. 17735-24

Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No.	Page
N278	VD	6019	ME	CAL	0026	of 10

To be recalculated based on the comments on previous pages.

summary

	1 <sup>st</sup> stage	2 <sup>nd</sup> stage	
$V_s$	35,0	14,1	dm <sup>3</sup>
$V_d$	23,0	16,6	dm <sup>3</sup>
<b>Sizes are too small for API 618, minimum sizes of 0,03 m<sup>3</sup> (30 dm<sup>3</sup>) must be used. Therefor the final volumes are as per below.</b>			
	1 <sup>st</sup> stage	2 <sup>nd</sup> stage	
$V_s$	35,0	30,0	dm <sup>3</sup>
$V_d$	30,0	30,0	dm <sup>3</sup>

para 7.9.4.2.5.2

1<sup>st</sup> stage

$$P_{cf} = 3 \cdot 2,453 = 7,358 \%$$

According to para 7.9.4.2.5.2  $P_{cf} \leq 7 \%$

7,358 % is slightly more than 7%, but acceptable according to 7.9.4.2.5.2.1. with the following note;

Pulsation dampener will be sized as per API 618 0,03m<sup>3</sup> the remaining volume is from the inlet piping since there is no check valve.

2<sup>nd</sup> stage

$$P_{cf} = 3 \cdot 1,357 = 4,072 \%$$

According to para 7.9.4.2.5.2  $P_{cf} \leq 7 \%$

4,072 % is less than 7%, therefor accepted.

It seems that you do not understand this clu. of API well. It means that pressure pulsation at compressor flange shall be less than calculated value or 7% whichever is less. As per calculated value acceptable pulsation at compressor flange are 7 and 4.07 accordingly. Please recheck and update the description.

Pulsation Study Approach 1 Calculations

Document No. 17735-24

Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No	Revision
N278	VD	6019	ME	CAL	0026	03

Page

Page 9 of 10

para 7.9.4.2.5.3.1

1<sup>st</sup> stage

$$\Delta p = 1,67 \left( \frac{2,453 - 1}{2,453} \right) = 0,989 \%$$

0,989 % of 23,3 bar discharge pressure is 0,23 bar. Which is higher than the calculated differential pressure across the pulsation dampeners. (0.12bar)

2<sup>nd</sup> stage

$$\Delta p = 1,67 \left( \frac{1,357 - 1}{1,357} \right) = 0,439 \%$$

0,439 % of 30 bar discharge pressure is 0,13 bar, Which is higher than the calculated differential pressure across the pulsation dampeners. (0.08bar)

Pulsation Study Approach 1 Calculations

Document No. 17735-24

Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No	Revision	Page
N278	VD	6019	ME	CAL	0026	03	Page 10 of 10

**para 7.9.4.2.5.2.2.1**

Maximum allowable peak-to-peak pulsation level at any discrete frequency, expressed as a percentage of average mean absolute pressure.

**1<sup>st</sup> stage suction**

$$P_l = \frac{4,1}{(9,500)^{1/3}} = 1,936 \%$$

Maximum allowable peak to peak is 1,936 % is 0.45bar. The calculated differential pressure is 0.12bar is within this range.

**1<sup>st</sup> stage discharge**

$$P_l = \frac{4,1}{(17,368)^{1/3}} = 1,583 \%$$

Maximum allowable peak to peak is 1,583 % is 0.37bar. The calculated differential pressure is 0.12bar is within this range.

**2<sup>nd</sup> stage suction**

$$P_l = \frac{4,1}{(22,100)^{1/3}} = 1,461 \%$$

Maximum allowable peak to peak is 1,461 % is 0.44bar. The calculated differential pressure is 0.08bar is within this range.

**2<sup>nd</sup> stage discharge**

$$P_l = \frac{4,1}{(26,250)^{1/3}} = 1,380 \%$$

Maximum allowable peak to peak is 1,380 % is 0.41bar. The calculated differential pressure is 0.08bar is within this range.

It seems that you do not understand this clu. of API well. It means that pressure pulsation after pulsation damper shall be less than calculated value. Please be noted that pressure pulsation is differ from pressure drop.