



LIDCO, Pars SEE Zone, Assaluyeh,
Integrated Methanol and Ammonia
Plant 3000 MTPD MeOH / 900 MTPD NH3 PROJECT



Pulsation Study Approach 1 Calculations

Document No. 17735-24

Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No	Revision	Page
N278	VD	6019	ME	CAL	0026	05	Page 1 of 10

Pulsation Study Approach 1 Calculations

Code 1
M.Dalakeh

05	02-08-2024	Issued for Information	S.K.	J.J.	S.K.
04	15-07-2024	Issued for Information	K.P.	J.J.	S.K.
03	20-06-2024	Issued for Information	S.K.	J.J.	S.K.
02	13-12-2023	Issued for Information	S.K.	J.J.	S.K.
01	14-09-2023	Issued for Information	S.K.	J.J.	S.K.
REV.	DATE	DESCRIPTION	DRAWN	CHECKED	APPROVED

This document has been produced by Contractor for LIDCO. It is confidential and cannot be disclosed to or used by any third party for any purpose without prior written consent.

Pulsation Study Approach 1 Calculations

Document No. 17735-24

Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No	Revision	Page
N278	VD	6019	ME	CAL	0026	05	Page 2 of 10

LIST OF REVISED PAGES

Rev. Page	01	02	03	04	05	06	07	08	09	10	Rev. Page	01	02	03	04	05	Rev. Page	01	02	03	04	05
1	X	X	X	X	X						51						76					
2	X	X	X	X	X						52						77					
3	X	X	X	X	X						53						78					
4	X	X	X	X	X						54						79					
5	X	X	X	X	X						55						80					
6	X	X	X	X	X						56						81					
7	X	X	X	X	X						57						82					
8	X	X	X	X	X						58						83					
9	X	X	X	X	X						59						84					
10		X	X	X	X						60						85					
11				X							61						86					
12											62						87					
13											63						88					
14											64						89					
15											65						90					
16											66						91					
17											67						92					
18											68						ATTACHMENT					
19											69						1					
20											70						2					
21											71						3					
22											72						4					
23											73						5					
24											74						6					
25											75						7					



LIDCO, Pars SEE Zone, Assaluyeh,
Integrated Methanol and Ammonia
Plant 3000 MTPD MeOH / 900 MTPD NH3 PROJECT



Pulsation Study Approach 1 Calculations

Document No. 17735-24

Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No	Revision	Page
N278	VD	6019	ME	CAL	0026	05	Page 3 of 10

Design approach 1 in accordance with API 618

Project: Integrated Methanol and Ammonia Plant
Location: Iran
Equipment: Air Compressor
Purchase order: LIDCO-PO-NEC-278-6019
Airpack reference: 17735-COM

Requirements

Pulsation levels have to meet the limits as per paragraph 7.9.4.2.5.2.2.1 as well as the criteria in paragraph 7.9.2 through 7.9.3.

para 7.9.4.2.5.2.5.1

The peak-to-peak cyclic stress range is far below 180 N/mm^2 , therefore this paragraph is considered as not applicable.

Pulsation Study Approach 1 Calculations

Document No. 17735-24

Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No	Revision	Page
N278	VD	6019	ME	CAL	0026	05	Page 4 of 10

para 7.9.3.2

$$V_s = 8,1 \cdot PD \cdot \left(\frac{k \cdot T_s}{M} \right)^{1/4}$$

$$V_d = 1,6 \cdot \left(\frac{V_s}{(R)^{1/k}} \right)$$

$$V_s \geq V_d$$

$$V_s \geq 0,03 \text{ m}^3$$

$$V_d \geq 0,03 \text{ m}^3$$

$$\frac{l}{ID} \leq 4.0$$

- V_s = minimum required suction surge volume [m³]
 V_d = minimum required discharge surge volume [m³]
 K = isentropic compression exponent at average operating gas pressure and temperature
 T_s = absolute suction temperature [K]
 M = molecular weight
 PD = total net displaced volume per revolution of all compressor cylinders to be manifolded in the surge volume
 R = stage pressure ratio at cylinder flanges (= quotient of absolute discharge and suction pressures)
 l = surge volume length
 ID = surge volume inside diameter

Pulsation Study Approach 1 Calculations

Document No. 17735-24

Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No	Revision	Page
N278	VD	6019	ME	CAL	0026	05	Page 5 of 10

para 7.9.4.2.5.2

$$P_{cf} = 3R \%$$

$$P_{cf} \leq 7 \%$$

P_{cf} = maximum allowable unfiltered peak-to-peak pulsation level, as a percentage of average absolute line pressure at the compressor cylinder flange [%]

para 7.9.4.2.5.3.1

$$\Delta p = \frac{1,67 \cdot (R - 1)}{R}$$

$$\Delta p \leq 0,25 \%$$

Δp = maximum pressure drop based on steady flow through a pulsation suppression device, as a percentage of the average absolute line pressure at the inlet of the device [%]

R = stage pressure ratio at cylinder flanges (= quotient of absolute discharge and suction pressures)

para 7.9.2

The gas composition, specified in the purchaser datasheet is considered as the basis of this calculation.

para 7.9.4.2.5.2.2.1

$$P_l = \frac{4,1}{(P_L)^{1/3}}$$

P_l = maximum allowable peak-to-peak pulsation level at any discrete frequency, as a percentage of average absolute pressure [%]

P_L = average absolute line pressure [bar(a)]

Pulsation Study Approach 1 Calculations

Document No. 17735-24

Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No	Revision	Page
N278	VD	6019	ME	CAL	0026	05	Page 6 of 10

Input

		stage 1	stage 2	
K	isentropic compression exponent	1,4	1,4	
T_s	abs. suction temperature	319,15	333,15	K
M	molecular weight	28,959	28,959	
PD	total net displaced volume per revolution	2,376 E-3 [note 1]	9,621 E-4 [note 2]	m ³
R	stage pressure ratio	2,314	1,342	
P_L	avg abs. line pressure	17,032	25,742	Bar(a)

Compressor stage data

	1 st stage	2 nd stage	Unit
Suction pressure	10,5	23,1	Bar(a)
Discharge pressure	24,3	31	Bar(a)
Pressure ratio	2,314	1,342	
Suction temperature	319,15	333,15	K

[note 1]

1st stage

stroke 130 mm
cyl bore 55 mm
rod dia 30 mm
Single acting

$$PD = \frac{1}{4} \pi (0,055)^2 \cdot 0,13 = 2,376 \cdot 10^{-3} m^3$$

[note 2]

2nd stage

stroke 130 mm
cyl bore 35 mm
rod dia 30 mm
Single acting

$$PD = \frac{1}{4} \pi (0,035)^2 \cdot 0,13 = 9,621 \cdot 10^{-4} m^3$$

Pulsation Study Approach 1 Calculations

Document No. 17735-24

Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No	Revision	Page
N278	VD	6019	ME	CAL	0026	05	Page 7 of 10

Output

para 7.9.3.2

1st stage

$$V_s = 8,1 \cdot 2,376 \cdot 10^{-3} \cdot \left(\frac{1,4 \cdot 319,15}{28,959} \right)^{1/4} = 0,0381 \text{ m}^3 = 38,1 \text{ dm}^3$$

$$V_d = 1,6 \cdot \left(\frac{0,0381}{(2,314)^{1/1,4}} \right) = 0,0322 \text{ m}^3 = 32,2 \text{ dm}^3$$

$$V_s \geq V_d \text{ True}$$

$$V_s \geq 0,03 \text{ m}^3 \text{ True, so } V_s = 0,0381 \text{ m}^3$$

$$V_d \geq 0,03 \text{ m}^3 \text{ True, so } V_d = 0,0322 \text{ m}^3$$

2nd stage

$$V_s = 8,1 \cdot 9,621 \cdot 10^{-4} \cdot \left(\frac{1,4 \cdot 333,15}{28,959} \right)^{1/4} = 0,0156 \text{ m}^3 = 15,6 \text{ dm}^3$$

$$V_d = 1,6 \cdot \left(\frac{0,0156}{(1,342)^{1/1,4}} \right) = 0,0202 \text{ m}^3 = 20,2 \text{ dm}^3$$

Some of the following 3 equations are not true, hence calculated sizes are not acceptable. Sizes are too small for API 618, minimum sizes of 0,03 m³ must be used.

$$V_s \geq V_d \text{ Not True, so } V_s = 0,03 \text{ m}^3$$

$$V_s \geq 0,03 \text{ m}^3 \text{ Not True, so } V_s = 0,03 \text{ m}^3$$

$$V_d \geq 0,03 \text{ m}^3 \text{ Not True, so } V_d = 0,03 \text{ m}^3$$

Pulsation Study Approach 1 Calculations

Document No. 17735-24

Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No	Revision	Page
N278	VD	6019	ME	CAL	0026	05	Page 8 of 10

summary

Some sizes are too small for API 618, minimum sizes of 0,03 m³ (30 dm³) must be used. Therefore the final minimum suction and discharge volumes are as per below.

	1 st stage	2 nd stage	
V_s	38,1	30,0	dm ³
V_d	32,2	30,0	dm ³

para 7.9.4.2.5.2.1

1st stage

$$P_{cf} = 3 \cdot 2,314 = 6.942 \%$$

According to para 7.9.4.2.5.2.1 the cylinder flange pressure pulsation P_{cf} shall be limited at the lesser of 7% or the value from the above equation.

6.942 % is less than 7%, therefore the pulsation have to be lower than 6.942%, this is acceptable as per compressor information

2nd stage

$$P_{cf} = 3 \cdot 1,342 = 4,026 \%$$

According to para 7.9.4.2.5.2.1 the cylinder flange pressure pulsation P_{cf} shall be limited at the lesser of 7% or the value from the above equation.

4.026 % is less than 7%, therefore the pulsation have to be lower then 4.026%, this is acceptable as per compressor information

Pulsation Study Approach 1 Calculations

Document No. 17735-24

Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No	Revision	Page
N278	VD	6019	ME	CAL	0026	05	Page 9 of 10

para 7.9.4.2.5.3.1

1st stage

$$\Delta p = 1,67 \left(\frac{2,453 - 1}{2,453} \right) = 0,989 \%$$

0,989 % of 23,3 bar discharge pressure is 0,23 bar. Which is higher than the calculated differential pressure across the pulsation dampeners. (0.12bar)

2nd stage

$$\Delta p = 1,67 \left(\frac{1,357 - 1}{1,357} \right) = 0,439 \%$$

0,439 % of 30 bar discharge pressure is 0,13 bar, Which is higher than the calculated differential pressure across the pulsation dampeners. (0.08bar)

Pulsation Study Approach 1 Calculations

Document No. 17735-24

Page

Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No	Revision	Page
N278	VD	6019	ME	CAL	0026	05	Page 10 of 10

para 7.9.4.2.5.2.2.1

Maximum allowable peak-to-peak pulsation level at any discrete frequency, expressed as a percentage of average mean absolute pressure.

1st stage suction

$$P_l = \frac{4,1}{(9,500)^{1/3}} = 1,936 \%$$

Maximum allowable peak to peak is 1,936 % is 0.45bar. The calculated peak to peak is significantly lower due to pulsation dampers

1st stage discharge

$$P_l = \frac{4,1}{(17,368)^{1/3}} = 1,583 \%$$

Maximum allowable peak to peak is 1,583 % is 0.37bar. The calculated peak to peak is significantly lower due to pulsation dampers

2nd stage suction

$$P_l = \frac{4,1}{(22,100)^{1/3}} = 1,461 \%$$

Maximum allowable peak to peak is 1,461 % is 0.44bar. The calculated peak to peak is significantly lower due to pulsation dampers

2nd stage discharge

$$P_l = \frac{4,1}{(26,250)^{1/3}} = 1,380 \%$$

Maximum allowable peak to peak is 1,380 % is 0.41bar. The calculated peak to peak is significantly lower due to pulsation dampers