



LIDCO, Pars SEE Zone, Assaluyeh,  
Integrated Methanol and Ammonia  
Plant 3000 MTPD MeOH / 900 MTPD NH3 PROJECT



Pulsation Study Approach 1 Calculations



Document No. 17735-24

Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No	Revision
N278	VD	6019	ME	CAL	0026	02

Page

Page 1 of 9

## Pulsation Study Approach 1 Calculations

REV.	DATE	DESCRIPTION	DRAWN	CHECKED	APPROVED
02	13-12-2023	Issued for Information	S.K.	J.J.	S.K.
01	14-09-2023	Issued for Information	S.K.	J.J.	S.K.

This document has been produced by Contractor for LIDCO. It is confidential and cannot be disclosed to or used by any third party for any purpose without prior written consent.

Pulsation Study Approach 1 Calculations

Document No. 17735-24

Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No	Revision	Page
N278	VD	6019	ME	CAL	0026	02	Page 2 of 9

LIST OF REVISED PAGES

Rev. Page	01	02	03	04	05	Rev. Page	01	02	03	04	05	Rev. Page	01	02	03	04	05	Rev. Page	01	02	03	04	05	
1	X					26						51						76						
2	X					27						52						77						
3	X					28						53						78						
4	X					29						54						79						
5	X					30						55						80						
6	X					31						56						81						
7	X					32						57						82						
8	X					33						58						83						
9	X					34						59						84						
10						35						60						85						
11						36						61						86						
12						37						62						87						
13						38						63						88						
14						39						64						89						
15						40						65						90						
16						41						66						91						
17						42						67						92						
18						43						68						ATTACHMENT						
19						44						69						1						
20						45						70						2						
21						46						71						3						
22						47						72						4						
23						48						73						5						
24						49						74						6						
25						50						75						7						



LIDCO, Pars SEE Zone, Assaluyeh,  
Integrated Methanol and Ammonia  
Plant 3000 MTPD MeOH / 900 MTPD NH3 PROJECT



Pulsation Study Approach 1 Calculations

Document No. 17735-24

Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No	Revision	Page
N278	VD	6019	ME	CAL	0026	02	Page 3 of 9

### Design approach 1 in accordance with API 618

Project: Integrated Methanol and Ammonia Plant  
Location: Iran  
Equipment: Air Compressor  
Purchase order: LIDCO-PO-NEC-278-6019  
Airpack reference: 17735-COM

### Requirements

Pulsation levels have to meet the limits as per paragraph 7.9.4.2.5.2.2.1 as well as the criteria in paragraph 7.9.2 through 7.9.3.

#### para 7.9.4.2.5.2.5.1

The peak-to-peak cyclic stress range is far below  $180 \text{ N/mm}^2$ , therefore this paragraph is considered as not applicable.

Pulsation Study Approach 1 Calculations

Document No. 17735-24

Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No	Revision	Page
N278	VD	6019	ME	CAL	0026	02	Page 4 of 9

para 7.9.3.2

$$V_s = 8,1 \cdot PD \cdot \left( \frac{k \cdot T_s}{M} \right)^{1/4}$$

$$V_d = 1,6 \cdot \left( \frac{V_s}{(R)^{1/k}} \right)$$

$$V_s \geq V_d$$

$$V_s \geq 0,03 \text{ m}^3$$

$$V_d \geq 0,03 \text{ m}^3$$

$$\frac{l}{ID} \leq 4.0$$

- $V_s$  = minimum required suction surge volume [m<sup>3</sup>]  
 $V_d$  = minimum required discharge surge volume [m<sup>3</sup>]  
 $K$  = isentropic compression exponent at average operating gas pressure and temperature  
 $T_s$  = absolute suction temperature [K]  
 $M$  = molecular weight  
 $PD$  = total net displaced volume per revolution of all compressor cylinders to be manifolded in the surge volume  
 $R$  = stage pressure ratio at cylinder flanges ( = quotient of absolute discharge and suction pressures)  
 $l$  = surge volume length  
 $ID$  = surge volume inside diameter

Pulsation Study Approach 1 Calculations

Document No. 17735-24

Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No	Revision	Page
N278	VD	6019	ME	CAL	0026	02	Page 5 of 9

para 7.9.4.2.5.2

$$P_{cf} = 3R \%$$

$$P_{cf} \leq 7 \%$$

$P_{cf}$  = maximum allowable unfiltered peak-to-peak pulsation level, as a percentage of average absolute line pressure at the compressor cylinder flange [%]

para 7.9.4.2.5.3.1

$$\Delta p = \frac{1,67 \cdot (R - 1)}{R}$$

$$\Delta p \leq 0,25 \%$$

$\Delta p$  = maximum pressure drop based on steady flow through a pulsation suppression device, as a percentage of the average absolute line pressure at the inlet of the device [%]

$R$  = stage pressure ratio at cylinder flanges ( = quotient of absolute discharge and suction pressures)

para 7.9.2

The gas composition at 1<sup>st</sup> year summer is considered as the basis of this calculation. No other gas compositions are considered. During sizing of the compressors all 6 scenarios have been calculated, and differences are negligible.

para 7.9.4.2.5.2.2.1

$$P_l = \frac{4,1}{(P_L)^{1/3}}$$

$P_l$  = maximum allowable peak-to-peak pulsation level at any discrete frequency, as a percentage of average absolute pressure [%]

$P_L$  = average absolute line pressure [bar(a)]

Pulsation Study Approach 1 Calculations

Document No. 17735-24

Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No	Revision	Page
N278	VD	6019	ME	CAL	0026	02	Page 6 of 9

Input

		stage 1	stage 2	
$K$	isentropic compression exponent	0,9991	0,9982	
$T_s$	abs. suction temperature	313,15	313,15	K
$M$	molecular weight	28,959	28,959	
$PD$	total net displaced volume per revolution	2,259 E-3 [note 1]	8,451 E-4 [note 2]	$m^3$
$R$	stage pressure ratio	2,453	1,357	
$P_L$	avg abs. line pressure	17,368	26,250	kg/cm <sup>2</sup> (a)

Compressor stage data

	1 <sup>st</sup> stage	2 <sup>nd</sup> stage	Unit
Suction pressure	9,5	22,1	Bar
Discharge pressure	23,3	30	Bar
Pressure ratio	2,453	1,357	
Suction temperature	313,15	313,15	K

[note 1]

1<sup>st</sup> stage

stroke 130 mm  
cyl bore 55 mm  
rod dia 30 mm  
Single acting

$$PD = \frac{1}{4} \pi (0,055)^2 - (0,030)^2 \cdot 0,13 = 2,259 \cdot 10^{-3} m^3$$

[note 2]

2<sup>nd</sup> stage

stroke 130 mm  
cyl bore 35 mm  
rod dia 30 mm  
Single acting

$$PD = \frac{1}{4} \pi (0,035)^2 - (0,030)^2 \cdot 0,13 = 8,451 \cdot 10^{-4} m^3$$

Pulsation Study Approach 1 Calculations

Document No. 17735-24

Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No	Revision	Page
N278	VD	6019	ME	CAL	0026	02	Page 7 of 9

**Output**

**para 7.9.3.2**

**1<sup>st</sup> stage**

$$V_s = 8,1 \cdot 2,459 \cdot 10^{-3} \cdot \left( \frac{0,9991 \cdot 313,15}{28,959} \right)^{1/4} = 0,033 \text{ m}^3 = 33 \text{ dm}^3$$

$$V_d = 1,6 \cdot \left( \frac{0,033}{(2,453)^{1/0,9991}} \right) = 0,022 \text{ m}^3 = 22 \text{ dm}^3$$

Some of the following 3 equations are not true, hence calculated sizes are not acceptable. Sizes are too small for API 618, minimum sizes of 0,03 m<sup>3</sup> must be used.

$$V_s \geq V_d \text{ True}$$

$$V_s \geq 0,03 \text{ m}^3 \text{ True}$$

$$V_d \geq 0,03 \text{ m}^3 \text{ not true! } V_d = 0,022 \text{ m}^3, \text{ according to API 618} \rightarrow V_d = 0,03 \text{ m}^3.$$

**2<sup>nd</sup> stage**

$$V_s = 8,1 \cdot 8,451 \cdot 10^{-4} \cdot \left( \frac{0,9982 \cdot 313,15}{28,959} \right)^{1/4} = 0,012408 \text{ m}^3 = 12,4 \text{ dm}^3$$

$$V_d = 1,6 \cdot \left( \frac{0,012408}{(1,357)^{1/0,9982}} \right) = 0,014617 \text{ m}^3 = 14,6 \text{ dm}^3$$

Some of the following 3 equations are not true, hence calculated sizes are not acceptable. Sizes are too small for API 618, minimum sizes of 0,03 m<sup>3</sup> must be used.

$$V_s \geq V_d \text{ Not True, so } V_s = 0,03 \text{ m}^3$$

$$V_s \geq 0,03 \text{ m}^3 \text{ Not True, so } V_s = 0,03 \text{ m}^3$$

$$V_d \geq 0,03 \text{ m}^3 \text{ Not True, so } V_d = 0,03 \text{ m}^3$$

Pulsation Study Approach 1 Calculations

Document No. 17735-24

Page

Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No	Revision	Page
N278	VD	6019	ME	CAL	0026	02	Page 8 of 9

summary

	1 <sup>st</sup> stage	2 <sup>nd</sup> stage	
$V_s$	33,0	12,4	dm <sup>3</sup>
$V_d$	22,0	14,6	dm <sup>3</sup>

Sizes are too small for API 618, minimum sizes of 0,03 m<sup>3</sup> (30 dm<sup>3</sup>) must be used. Therefor the final volume is equal to 0,03 m<sup>3</sup>.

para 7.9.4.2.5.2

1<sup>st</sup> stage

$$P_{cf} = 3 \cdot 2,453 = 7,359 \%$$

7,359 % is slightly more, but acceptable according to 7.9.4.2.5.2.1, since pulsation dampener will be sized bigger as per API 618, minimum size of 0,03m<sup>3</sup>.

2<sup>nd</sup> stage

$$P_{cf} = 3 \cdot 1,357 = 4,071 \%$$

4,071 % is less than 7%, therefor accepted.

para 7.9.4.2.5.3.1

1<sup>st</sup> stage

$$\Delta p = 1,67 \left( \frac{2,453 - 1}{2,453} \right) = 0,989 \%$$

0,989 % of 23,3 bar discharge pressure is 0,23 bar, which is below the required 0,25 bar.

2<sup>nd</sup> stage

$$\Delta p = 1,67 \left( \frac{1,357 - 1}{1,357} \right) = 0,439 \%$$

0,439 % of 30 bar discharge pressure is 0,13 bar, which is below the required 0,25 bar.

Pulsation Study Approach 1 Calculations

Document No. 17735-24

Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No	Revision	Page
N278	VD	6019	ME	CAL	0026	02	Page 9 of 9

para 7.9.4.2.5.2.2.1

Maximum allowable peak-to-peak pulsation level at any discrete frequency, expressed as a percentage of average mean absolute pressure.

1<sup>st</sup> stage suction

$$P_l = \frac{4,1}{(9,500)^{1/3}} = 1,936 \%$$

1<sup>st</sup> stage discharge

$$P_l = \frac{4,1}{(17,368)^{1/3}} = 1,583 \%$$

2<sup>nd</sup> stage suction

$$P_l = \frac{4,1}{(22,100)^{1/3}} = 1,461 \%$$

2<sup>nd</sup> stage discharge

$$P_l = \frac{4,1}{(26,250)^{1/3}} = 1,380 \%$$