



LIDCO, Pars SEE Zone, Assaluyeh,
Integrated Methanol and Ammonia
Plant 3000 MTPD MeOH / 900 MTPD NH3 PROJECT



Pulsation Study Approach 1 Calculations

Document No. 17735-24

Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No	Revision	Page
N278	VD	6019	ME	CAL	0026	03	Page 1 of 10

Pulsation Study Approach 1 Calculations

REV.	DATE	DESCRIPTION	DRAWN	CHECKED	APPROVED
03	20-06-2024	Issued for Information	S.K.	J.J.	S.K.
02	13-12-2023	Issued for Information	S.K.	J.J.	S.K.
01	14-09-2023	Issued for Information	S.K.	J.J.	S.K.

This document has been produced by Contractor for LIDCO. It is confidential and cannot be disclosed to or used by any third party for any purpose without prior written consent.

Pulsation Study Approach 1 Calculations

Document No. 17735-24

Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No	Revision	Page
N278	VD	6019	ME	CAL	0026	03	Page 2 of 10

LIST OF REVISED PAGES

Rev. Page	01	02	03	04	05	Rev. Page	01	02	03	04	05	Rev. Page	01	02	03	04	05	Rev. Page	01	02	03	04	05
1	X	X				26						51						76					
2	X	X				27						52						77					
3	X	X				28						53						78					
4	X	X				29						54						79					
5	X	X				30						55						80					
6	X	X				31						56						81					
7	X	X				32						57						82					
8	X	X				33						58						83					
9	X	X				34						59						84					
10		X				35						60						85					
11						36						61						86					
12						37						62						87					
13						38						63						88					
14						39						64						89					
15						40						65						90					
16						41						66						91					
17						42						67						92					
18						43						68						ATTACHMENT					
19						44						69						1					
20						45						70						2					
21						46						71						3					
22						47						72						4					
23						48						73						5					
24						49						74						6					
25						50						75						7					



LIDCO, Pars SEE Zone, Assaluyeh,
Integrated Methanol and Ammonia
Plant 3000 MTPD MeOH / 900 MTPD NH3 PROJECT



Pulsation Study Approach 1 Calculations

Document No. 17735-24

Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No	Revision	Page
N278	VD	6019	ME	CAL	0026	03	Page 3 of 10

Design approach 1 in accordance with API 618

Project: Integrated Methanol and Ammonia Plant
Location: Iran
Equipment: Air Compressor
Purchase order: LIDCO-PO-NEC-278-6019
Airpack reference: 17735-COM

Requirements

Pulsation levels have to meet the limits as per paragraph 7.9.4.2.5.2.2.1 as well as the criteria in paragraph 7.9.2 through 7.9.3.

para 7.9.4.2.5.2.5.1

The peak-to-peak cyclic stress range is far below 180 N/mm^2 , therefore this paragraph is considered as not applicable.

Pulsation Study Approach 1 Calculations

Document No. 17735-24

Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No	Revision	Page
N278	VD	6019	ME	CAL	0026	03	Page 4 of 10

para 7.9.3.2

$$V_s = 8,1 \cdot PD \cdot \left(\frac{k \cdot T_s}{M} \right)^{1/4}$$

$$V_d = 1,6 \cdot \left(\frac{V_s}{(R)^{1/k}} \right)$$

$$V_s \geq V_d$$

$$V_s \geq 0,03 \text{ m}^3$$

$$V_d \geq 0,03 \text{ m}^3$$

$$\frac{l}{ID} \leq 4.0$$

- V_s = minimum required suction surge volume [m³]
 V_d = minimum required discharge surge volume [m³]
 K = isentropic compression exponent at average operating gas pressure and temperature
 T_s = absolute suction temperature [K]
 M = molecular weight
 PD = total net displaced volume per revolution of all compressor cylinders to be manifolded in the surge volume
 R = stage pressure ratio at cylinder flanges (= quotient of absolute discharge and suction pressures)
 l = surge volume length
 ID = surge volume inside diameter

Pulsation Study Approach 1 Calculations

Document No. 17735-24

Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No	Revision	Page
N278	VD	6019	ME	CAL	0026	03	Page 5 of 10

para 7.9.4.2.5.2

$$P_{cf} = 3R \%$$

$$P_{cf} \leq 7 \%$$

P_{cf} = maximum allowable unfiltered peak-to-peak pulsation level, as a percentage of average absolute line pressure at the compressor cylinder flange [%]

para 7.9.4.2.5.3.1

$$\Delta p = \frac{1,67 \cdot (R - 1)}{R}$$

$$\Delta p \leq 0,25 \%$$

Δp = maximum pressure drop based on steady flow through a pulsation suppression device, as a percentage of the average absolute line pressure at the inlet of the device [%]

R = stage pressure ratio at cylinder flanges (= quotient of absolute discharge and suction pressures)

para 7.9.2

The gas composition, specified in the purchaser datasheet is considered as the basis of this calculation.

para 7.9.4.2.5.2.2.1

$$P_l = \frac{4,1}{(P_L)^{1/3}}$$

P_l = maximum allowable peak-to-peak pulsation level at any discrete frequency, as a percentage of average absolute pressure [%]

P_L = average absolute line pressure [bar(a)]

Pulsation Study Approach 1 Calculations

Document No. 17735-24

Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No	Revision
N278	VD	6019	ME	CAL	0026	03

Page

Page 6 of 10

Input

		stage 1	stage 2	
K	isentropic compression exponent	0,9991	0,9982	
T_s	abs. suction temperature	313,15	313,15	K
M	molecular weight	28,959	28,959	
PD	total net displaced volume per revolution	2,259 E-3 [note 1]	8,451 E-4 [note 2]	m ³
R	stage pressure ratio	2,453	1,357	
P_L	avg abs. line pressure	17,368	26,250	kg/cm ² (a)

Compressor stage data

	1 st stage	2 nd stage	Unit
Suction pressure	9,5	22,1	Bar
Discharge pressure	23,3	30	Bar
Pressure ratio	2,453	1,357	
Suction temperature	313,15	313,15	K

[note 1]

1st stage

stroke 130 mm
cyl bore 55 mm
rod dia 30 mm
Single acting

$$PD = \frac{1}{4} \pi (0,055)^2 \cdot 0,13 = 2,376 \cdot 10^{-3} m^3$$

[note 2]

2nd stage

stroke 130 mm
cyl bore 35 mm
rod dia 30 mm
Single acting

$$PD = \frac{1}{4} \pi (0,035)^2 \cdot 0,13 = 9,621 \cdot 10^{-4} m^3$$

Pulsation Study Approach 1 Calculations

Document No. 17735-24

Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No	Revision	Page
N278	VD	6019	ME	CAL	0026	03	Page 7 of 10

Output

para 7.9.3.2

1st stage

$$V_s = 8,1 \cdot 2,376 \cdot 10^{-3} \cdot \left(\frac{0,9991 \cdot 313,15}{28,959} \right)^{1/4} = 0,035 \text{ m}^3 = 35 \text{ dm}^3$$

$$V_d = 1,6 \cdot \left(\frac{0,035}{(2,453)^{1/0,9991}} \right) = 0,023 \text{ m}^3 = 23 \text{ dm}^3$$

Some of the following 3 equations are not true, hence calculated sizes are not acceptable. Sizes are too small for API 618, minimum sizes of 0,03 m³ must be used.

$$V_s \geq V_d \text{ True}$$

$$V_s \geq 0,03 \text{ m}^3 \text{ True}$$

$$V_d \geq 0,03 \text{ m}^3 \text{ not true! } V_d = 0,023 \text{ m}^3, \text{ according to API 618} \rightarrow V_d = 0,03 \text{ m}^3.$$

2nd stage

$$V_s = 8,1 \cdot 9,621 \cdot 10^{-4} \cdot \left(\frac{0,9982 \cdot 313,15}{28,959} \right)^{1/4} = 0,0141 \text{ m}^3 = 14,1 \text{ dm}^3$$

$$V_d = 1,6 \cdot \left(\frac{0,0141}{(1,357)^{1/0,9982}} \right) = 0,0166 \text{ m}^3 = 16,6 \text{ dm}^3$$

Some of the following 3 equations are not true, hence calculated sizes are not acceptable. Sizes are too small for API 618, minimum sizes of 0,03 m³ must be used.

$$V_s \geq V_d \text{ Not True, so } V_s = 0,03 \text{ m}^3$$

$$V_s \geq 0,03 \text{ m}^3 \text{ Not True, so } V_s = 0,03 \text{ m}^3$$

$$V_d \geq 0,03 \text{ m}^3 \text{ Not True, so } V_d = 0,03 \text{ m}^3$$

Pulsation Study Approach 1 Calculations

Document No. 17735-24

Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No	Revision	Page
N278	VD	6019	ME	CAL	0026	03	Page 8 of 10

summary

	1 st stage	2 nd stage	
V_s	35,0	14,1	dm ³
V_d	23,0	16,6	dm ³

Sizes are too small for API 618, minimum sizes of 0,03 m³ (30 dm³) must be used. Therefor the final volumes are as per below.

	1 st stage	2 nd stage	
V_s	35,0	30,0	dm ³
V_d	30,0	30,0	dm ³

para 7.9.4.2.5.2

1st stage

$$P_{cf} = 3 \cdot 2,453 = 7,358 \%$$

According to para 7.9.4.2.5.2 $P_{cf} \leq 7 \%$

7,358 % is slightly more than 7%, but acceptable according to 7.9.4.2.5.2.1. with the following note;

Pulsation dampener will be sized as per API 618 0,03m³ the remaining volume is from the inlet piping since there is no check valve.

2nd stage

$$P_{cf} = 3 \cdot 1,357 = 4,072 \%$$

According to para 7.9.4.2.5.2 $P_{cf} \leq 7 \%$

4,072 % is less than 7%, therefor accepted.

Pulsation Study Approach 1 Calculations

Document No. 17735-24

Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No	Revision	Page
N278	VD	6019	ME	CAL	0026	03	Page 9 of 10

para 7.9.4.2.5.3.1

1st stage

$$\Delta p = 1,67 \left(\frac{2,453 - 1}{2,453} \right) = 0,989 \%$$

0,989 % of 23,3 bar discharge pressure is 0,23 bar. Which is higher than the calculated differential pressure across the pulsation dampeners. (0.12bar)

2nd stage

$$\Delta p = 1,67 \left(\frac{1,357 - 1}{1,357} \right) = 0,439 \%$$

0,439 % of 30 bar discharge pressure is 0,13 bar, Which is higher than the calculated differential pressure across the pulsation dampeners. (0.08bar)

Pulsation Study Approach 1 Calculations

Document No. 17735-24

Page

Project No.	Vendor Doc.	P.O. No.	Department	Document Type	Serial No	Revision	Page
N278	VD	6019	ME	CAL	0026	03	Page 10 of 10

para 7.9.4.2.5.2.2.1

Maximum allowable peak-to-peak pulsation level at any discrete frequency, expressed as a percentage of average mean absolute pressure.

1st stage suction

$$P_l = \frac{4,1}{(9,500)^{1/3}} = 1,936 \%$$

Maximum allowable peak to peak is 1,936 % is 0.45bar. The calculated differential pressure is 0.12bar is within this range.

1st stage discharge

$$P_l = \frac{4,1}{(17,368)^{1/3}} = 1,583 \%$$

Maximum allowable peak to peak is 1,583 % is 0.37bar. The calculated differential pressure is 0.12bar is within this range.

2nd stage suction

$$P_l = \frac{4,1}{(22,100)^{1/3}} = 1,461 \%$$

Maximum allowable peak to peak is 1,461 % is 0.44bar. The calculated differential pressure is 0.08bar is within this range.

2nd stage discharge

$$P_l = \frac{4,1}{(26,250)^{1/3}} = 1,380 \%$$

Maximum allowable peak to peak is 1,380 % is 0.41bar. The calculated differential pressure is 0.08bar is within this range.