





OWNER:  شرکت پتروشیمی بوشهر	BUSHEHR MEG PLANT PETROCHEMICAL COMPANY		CONTRACTOR:  Chagalesh-Enerchimi-Steam Joint Venture BEPC-MEG PLANT PROJECT
	VENDOR CLARIFICATION SHEET		
	MR.No.&REV. BU-20-D-000-MA-MRQ-303-Rev-00	SUBJECT: REQUISITION FOR RECIPROCATING COMPRESSOR (ITEM C-1002 & C-7080)	
MC:   شرکت سفت و سوی توسعه ایرانیان	VENDOR NAME:	AIRPACK	REF.TRANSMITTAL No.
	QUOTATION No.:	INA	REF.DATE TRANSMITTAL :
	QUOTATION REV. & DATE:	17 Jul 2020 Rev.0	TCL No: TCL-RC-AIRPACK-R00

G14	Two years spare part list shall be in compliance with two years spare part attached to BU-20-D-000-MA-MRQ-303-Rev-00 Meanwhile, VENDOR shall propose his list of recommended 2 years spare parts, as well.	Refer to offer for included spare parts.	Spare part list as per BU-20-D-000-MA-MRQ-303-Rev-00 shall be followed by AIRPACK.	Spare parts according 52-15-631 BU-20-D-000-ME-MRQ-302A RECIPROCATING COMPRESSORS- Catic 2018-10-20	Closed. AIRPACK confirms to follow spare part list as per BU-20-D-000-MA-MRQ-303-Rev-00.
G15	VENDOR shall confirm that Vendor Print Index and schedule will cover the RFD of BU-20-D-000-MA-MRQ-303-Rev-00as minimum.	As per supplier data register in the offer.	RFD shall be confirmed by AIRPACK. VPIS will be finalized after P.O	We have provided list of documents in our offer, however, as stated by client, VPIS will be finalized in KOM.	Closed.
G16	VENDOR shall model the whole package with PDMS (Version 12). Please confirm.	Airpack will provide a STEP file which can be incorporated in Client PDMS.	Closed.		Closed.
G17	Following items shall be considered by VENDOR G17.1 HAZOP and SIL studies shall be done by vendor	G17.1 and G17.2 This is quoted as option. Any	G17.1 Closed. HAZOP and SIL	HAZOP/SIL meeting is	Closed.