









OWNER:  شرکت سست و پتروشیمی آریگان (سهای خصوصی)	BUSHEHR PETROCHEMICAL COMPANY MEG PLANT						EPC CONTRACTOR:  Chagalesh-Enerchimi-Steam Joint Venture BUPC-MEG PLANT PROJECT		
	PULSATION DAMPER MECHANICAL DATA SHEET FOR NITROGEN GAS BOOSTER								
MC : 	Project	Area	Phase	Unit	Dis.	Doc.	Seq.	Contract No : 52-98/445	
Owner Document Number: 17811-11C	BU	20	VD	303	ME	DSH	0027	Rev.:	Page
								03	1 of 4

PULSATION DAMPER MECHANICAL DATA SHEET FOR NITROGEN GAS BOOSTER



03	13/04/2022	For approval	KP	CL	JR		
02	10/03/2022	For approval	KP	CL	JR		
01	28/02/2022	For approval	KP	CL	JR		
00	11/12/2020	For approval	KP	KP	KP		
Rev.	Date	Purpose of Issue	Prepared	Checked	Approved	AC Code	
						Class: 11	Phase: p



OWNER:  شرکت سست موبلی آوند ایرانیا (سهانی نظام)	BUSHEHR PETROCHEMICAL COMPANY MEG PLANT						EPC CONTRACTOR:  Chagalesh-Enerchimi-Steam Joint Venture BUPC-MEG PLANT PROJECT		
	PULSATION DAMPER MECHANICAL DATA SHEET FOR NITROGEN GAS BOOSTER						 Netherlands		
MC :  شرکت سست موبلی آوند ایرانیا اصفهان	Project	Area	Phase	Unit	Dis.	Doc.	Seq.	Contract No : 52-98/445	
Owner Document Number: 17811-11C	BU	20	VD	303	ME	DSH	0027	Rev.:	Page
								03	2 of 4

TABULATION OF REVISED PAGES

Page	D00	D01	D02	D03	D04
1.	X	X	X	X	
2.	X	X	X	X	
3.	X	X	X	X	
4.		X	X	X	
5.					
6.					
7.					
8.					
9.					
10.					
11.					
12.					
13.					
14.					
15.					
16.					
17.					
18.					
19.					
20.					
21.					
22.					
23.					
24.					
25.					

Page	D00	D01	D02	D03	D04
35.					
36.					
37.					
38.					
39.					
40.					
41.					
42.					
43.					
44.					
45.					
46.					
47.					
48.					
49.					
50.					
51.					
52.					
53.					
54.					
55.					
56.					
57.					
58.					
59.					

		Pulsation damper mechanical datasheet		P.O. No.	52-98/445
				Document No.	17811-11C
				Sheet No.	3
				Rev.No	3
			BUSHEHR PETROCHEMICAL COMPANY MEG PLANT		
CONTRACTOR / END USER			Service: nitrogen compressor package		
1	1st stage inlet pulsation damper (20-DC-1002-1)				
2	OPERATING PRESSURE	Bar(a)	9 bar(a)		
3	DESIGN PRESSURE	Bar(g)	14,5 bar(g)		
4	HYDROTEST PRESSURE	1.3 X MAWP as per ASME VIII			
5	OPERATING TEMPERATURE	°C	5-52		
6	DESIGN TEMPERATURE	°C	0-85		
7	DESIGN CODE	ASME VIII Div. 1 Ed. 2021			
8	MATERIAL CERTIFICATE	3.1			
9	MATERIAL OF CONSTRUCTION	Shell /pipes : SA106 gr B, Heads : SA234 WPB, flanges : SA105			
10	NOZZLE SIZE INLET/OUTLET	2" 150# for inlet and outlet, 1/2 NPT-F for drain			
11	DIMENSIONS	DIAX TT	12" X 1100 mm		
12	WEIGHT EMPTY	kg	120		
13	WEIGHT FILLED WITH WATER	kg	210		
14	CAPACITY	Liters	96		
15	TESTING AS PER CODE	ASME VIII Div. 1 Ed. 2021			
16	CORROSION ALLOWANCE	mm	3		
17	PWHT	Yes/No	No		
18	THICKNESS	mm	9,52		
19	Design aproach	API 618 Design approach 2			
20	Maximum Allowable Compressor Cylinder Flange Pressure Pulsation as per clause 7.9.4.2.5.2.1 of API618.		6,64%		
21	Maximum Allowable Pressure Drop as per clause 7.9.4.2.5.3.1 of API 618.	Bar	0,18		
23	Maximum Allowable Pulsation Limits at and Beyond Line-side Nozzles of Pulsation Suppression Devices as per clause 7.9.4.2.5.2.2.1 of API 618.	bar	0,536		
24	1st stage outlet pulsation damper (20-DC-1002-2)				
25	OPERATING PRESSURE	Bar(a)	15,5 bar(a)		
26	DESIGN PRESSURE	Bar(g)	26 bar(g)		
27	HYDROTEST PRESSURE	1.3 X MAWP as per ASME VIII			
28	OPERATING TEMPERATURE	°C	134		
29	DESIGN TEMPERATURE	°C	0-170		
30	DESIGN CODE	ASME VIII Div. 1 Ed. 2021			
31	MATERIAL CERTIFICATE	3.1			
32	MATERIAL OF CONSTRUCTION	Shell /pipes : SA106 gr B, Heads : SA234 WPB, flanges : SA105			
33	NOZZLE SIZE INLET/OUTLET	2" 300# for inlet and outlet, 1/2 NPT-F for drain			
34	DIMENSIONS	DIAX TT	12" X 1100 mm		
35	WEIGHT EMPTY	kg	110		
36	WEIGHT FILLED WITH WATER	kg	190		
37	CAPACITY	Liters	96		
38	TESTING AS PER CODE	ASME VIII Div. 1 Ed. 2021			
39	CORROSION ALLOWANCE	mm	3		
40	PWHT	Yes/No	No		
41	THICKNESS	mm	9,52		
43	Design aproach	API 618 Design approach 2			
44	Maximum Allowable Compressor Cylinder Flange Pressure Pulsation as per clause 7.9.4.2.5.2.1 of API618.	Bar	6,64%		
45	Maximum Allowable Pressure Drop as per clause 7.9.4.2.5.3.1 of API 618.	Bar	0,15		
46	Maximum Allowable Pulsation Limits at and Beyond Line-side Nozzles of Pulsation Suppression Devices as per clause 7.9.4.2.5.2.2.1 of API 618.	bar	1,433		
47					
48					
49	NOTES:				
50					
51					
52					

		Pulsation damper mechanical datasheet		P.O. No.	52-98/445
				Document No.	17811-11C
				Sheet No.	4
				Rev.No	3
			BUSHEHR PETROCHEMICAL COMPANY MEG PLANT		Service
				nitrogen compressor package	
2nd stage inlet pulsation damper (20-DC-1002-3)					
2	OPERATING PRESSURE	Bar(a)		14,5 bar(a)	
3	DESIGN PRESSURE	Bar(g)		26 bar(g)	
4	HYDROTEST PRESSURE			1.3 X MAWP as per ASME VIII	
5	OPERATING TEMPERATURE	°C		50	
6	DESIGN TEMPERATURE	°C		0-85	
7	DESIGN CODE			ASME VIII Div. 1 Ed. 2021	
8	MATERIAL CERTIFICATE			3.1	
9	MATERIAL OF CONSTRUCTION			Shell /pipes : SA106 gr B, Heads : SA234 WPB, flanges : SA105	
10	NOZZLE SIZE INLET/OUTLET			2" 300# for inlet and outlet, 1/2 NPT-F for drain	
11	DIMENSIONS	DIxT		10" X 600 mm	
12	WEIGHT EMPTY	kg		75	
13	WEIGHT FILLED WITH WATER	kg		115	
14	CAPACITY	Liters		38	
15	TESTING AS PER CODE			ASME VIII Div. 1 Ed. 2021	
16	CORROSION ALLOWANCE	mm		3	
17	PWHT	Yes/No		No	
18	THICKNESS	mm		9,27	
20	Design approach			API 618 Design approach 2	
21	Maximum Allowable Compressor Cylinder Flange Pressure Pulsation as per clause 7.9.4.2.5.2.1 of API618.			4,54%	
22	Maximum Allowable Pressure Drop as per clause 7.9.4.2.5.3.1 of API 618.	Bar		0,0636	
23	Maximum Allowable Pulsation Limits at and Beyond Line-side Nozzles of Pulsation Suppression Devices as per clause 7.9.4.2.5.2.2.1 of API 618.	bar		0,739	
25	2nd stage outlet pulsation damper (20-DC-1002-4)				
26	OPERATING PRESSURE	Bar(a)		23,5 bar(a)	
27	DESIGN PRESSURE	Bar(g)		26 bar(g)	
28	HYDROTEST PRESSURE			1.3 X MAWP as per ASME VIII	
29	OPERATING TEMPERATURE	°C		83	
30	DESIGN TEMPERATURE	°C		0-85	
31	DESIGN CODE			ASME VIII Div. 1 Ed. 2021	
32	MATERIAL CERTIFICATE			3.1	
33	MATERIAL OF CONSTRUCTION			Shell /pipes : SA106 gr B, Heads : SA234 WPB, flanges : SA105	
34	NOZZLE SIZE INLET/OUTLET			2" 300# for inlet and outlet, 1/2 NPT-F for drain	
35	DIMENSIONS	DIxT		10" X 800 mm	
36	WEIGHT EMPTY	kg		85	
37	WEIGHT FILLED WITH WATER	kg		130	
38	CAPACITY	Liters		48	
39	TESTING AS PER CODE			ASME VIII Div. 1 Ed. 2021	
40	CORROSION ALLOWANCE	mm		3	
41	PWHT	Yes/No		No	
42	THICKNESS	mm		9,27	
44	Design approach			API 618 Design approach 2	
45	Maximum Allowable Compressor Cylinder Flange Pressure Pulsation as per clause 7.9.4.2.5.2.1 of API618.	Bar		4,54%	
46	Maximum Allowable Pressure Drop as per clause 7.9.4.2.5.3.1 of API 618.	Bar		0,0603	
47	Maximum Allowable Pulsation Limits at and Beyond Line-side Nozzles of Pulsation Suppression Devices as per clause 7.9.4.2.5.2.2.1 of API 618.	bar		0,9	
48	NOTES:				
49					
50					
51					