








OWNER:  شرکت سست و سویی توهر ایرانیاان (سهامی خاص)	BUSHEHR PETROCHEMICAL COMPANY MEG PLANT						EPC CONTRACTOR:  Chagalesh-Enerchimi-Steam Joint Venture BUPC-MEG PLANT PROJECT		
	SINGLE LINE DIAGRAM FOR POWER DISTRIBUTION PANEL FOR NITGROGEN GAS BOOSTER						 Netherlands		
MC :  شرکت سست و سویی توهر ایرانیاان (سهامی خاص)	Project	Area	Phase	Unit	Dis.	Doc.	Seq.	Contract No : 52-98/445	
Owner Document Number: 17811-49A	BU	20	VD	303	EL	DIG	0049	Rev.:	Page
								06	1 of 4

SINGLE LINE DIAGRAM FOR POWER DISTRIBUTION PANEL FOR NITGROGEN GAS BOOSTER

06	20/10/2022	Approved for Construction	MS	RB	KP	
05	14/09/2022	For approval	BK	RB	KP	
04	27/07/2022	For approval	BK	RB	KP	
03	28/06/2022	For approval	DH	RB	KP	
02	21/03/2022	For approval	AS	RB	KP	
01	10/01/2022	For approval	HT	RB	KP	
00	19/10/2021	For approval	HT	RB	KP	
Rev.	Date	Purpose of Issue	Prepared	Checked	Approved	AC Code
					Class: 1	Phase: P

OWNER:  شرکت سست و هوای توسعه ایرانین (سامی گاس)	BUSHEHR PETROCHEMICAL COMPANY MEG PLANT						EPC CONTRACTOR: 		
	SINGLE LINE DIAGRAM FOR POWER DISTRIBUTION PANEL FOR NITROGEN GAS BOOSTER								
MC :  شرکت سست و هوای توسعه ایرانین (سامی گاس)	Project	Area	Phase	Unit	Dis.	Doc.	Seq.	Contract No : 52-98/445	
Owner Document Number: 17811-49A	BU	20	VD	303	EL	DIG	0049	Rev.:	Page
								06	2 of 4

TABULATION OF REVISED PAGES

Page	D00	D01	D02	D03	D04
1.	X	X	X	X	X
2.	X	X	X	X	X
3.	X	X	X	X	X
4.	X	X		X	X
5.					
6.					
7.					
8.					
9.					
10.					

Page	D05	D06				
1.	X	X				
2.	X	X				
3.	X	X				
4.	X	X				
5.						
6.						
7.						
8.						
9.						
10.						

LEGEND



Maintenance switch



Circuit Breaker 3P (MPCB)



Circuit Breaker 3P (MCCB)



Circuit Breaker 3P (MCB)



Contactor 3P



Main Motor



Oilheater

NOTES:



SUBJECT		BUSHEHR PETROCHEMICAL COMPANY MEG PLANT EMERGENCY INSTRUMENT AIR COMPRESSOR	
CLIENT	BUSHEHR PETROCHEMICAL COMPANY (BUPC)	PLANT LOCATION	IRAN
CLIENT REF	20-C-1002-M	DRAWING NO.	17811-49A
AIRPACK REF	17811	SHEETNO.	03 / 04

DATE	14-09-2022
DRAWN BY	HT
CHECKED BY	KP

THIS DRAWING IS OWNED BY AIRPACK AND SHALL NOT BE PRINTED OR COPIED IN ANY OTHER WAY THAN WITH AIRPACKS PERMISSION

REV 06	20-10-2022	MS
REV 05	14-09-2022	BK
REV 04	25-07-2022	BK
REV 03	08-06-2022	DH
REV 02	18-03-2022	AS
REV 01	10-01-2022	HT
REV 00	09-10-2021	HT



SINGLE LINE DIAGRAM

From: 20-MS-SWB3B-01
 Cable no: EBP-20-C-1002-M
 Cable Type and Size: CU/XLPE/SWA/PVC3.5*150mm2
 Gland: EX-IP65 E/M63

UPS-1
 POWER SUPPLY
 110VAC 50 HZ
 3X2.5 mm2

UPS-2
 POWER SUPPLY
 110VAC 50 HZ
 3X2.5 mm2

NON-UPS
 POWER SUPPLY
 230VAC 50 HZ
 3X2.5 mm2



NOTES:



SUBJECT		BUSHEHR PETROCHEMICAL COMPANY MEG PLANT EMERGENCY INSTRUMENT AIR COMPRESSOR	
CLIENT	BUSHEHR PETROCHEMICAL COMPANY (BUPC)	PLANT LOCATION	IRAN
CLIENT REF	20-C-1002-M	DRAWING NO.	17811-49A
AIRPACK REF	17811	SHEETNO.	04/04

DATE	14-09-2022
DRAWN BY	HT
CHECKED BY	KP

THIS DRAWING IS OWNED BY AIRPACK AND SHALL NOT BE PRINTED OR COPIED IN ANY OTHER WAY THAN WITH AIRPACKS PERMISSION

REV 06	20-10-2022	MS
REV 05	14-09-2022	BK
REV 04	25-07-2022	BK
REV 03	08-06-2022	DH
REV 02	18-03-2022	AS
REV 01	10-01-2022	HT
REV 00	09-10-2021	HT