



Vendor 	ABT 360 KT/Y PP PLANT		Owner  سراج گستران رجال SERAJ GOSTARAN REJAL (سهایی خاص)
	Control Philosophy		
	Vendor's Doc. No.: 23249-21	Rev.: 03	
PPEC Doc. No.: L03-RE037-IN-PHY-001			

PPEC REQ. NO. : L03-RE037-IN-PHY-001

ITEM NO. :

TOTAL PAGES : 11



no comment

- **NO COMMENTS** : Documents/Drawings Were Checked By PPEC And Further Step Can Be Followed.
- **COMMENTED AS MARKED:** Documents/Drawings Were Checked By PPEC And Marked Comments Must Be Considered By Vendor. Vendor Shall Revise Documents/Drawing As Per Comments And The New Revision Of Documents/Drawings Must Be Revised Prior To Fabrication.
- **REJECTED:** Documents/Drawings Were Checked And It Is Not In Comply With Purchase Requisition Requirements.
- **ACCEPTABLE WITH COMMENTS:** Documents/Drawings Were Checked By PPEC And Comments Must Be Considered By Vendor. Fabrication Can Proceed Accordingly. Revised Document To Be Issued Either For Review Or As Final Certified. However PPEC Will Check The Revised Document For Proper Incorporation Of Comments.
- **NOT RETURNED:** Document Was Received For Information And Not Returned To The Vendor.

Name :	Req. No. :	Seq. No.:
Signature:		
Date :		



PPEC review & comments does not absolve the vendor of the responsibility for the corrected design, manufacturing and operation of the equipment

REV.	DATE	Description	Prepared by	Checked by	Approved by	Authorized by
03	15-08-2025	Issue for Engineering	S.K.	S.K.	B.S.	
02	21-07-2025	Issue for Engineering	S.K.	S.K.	B.S.	
01	27-05-2025	Issue for Engineering	S.K.	S.K.	B.S.	
00	18-04-2025	Issue for Engineering	S.K.	S.K.	B.S.	

Vendor	ABT 360 KT/Y PP PLANT	Contractor (DEC)	Owner
	Control Philosophy		
	Vendor's Doc. No.: 23249-21	Rev.: 03	سراج گستران رجال SERAJ GOSTARAN REJAL (سهامی خاص)
	PPEC Doc. No.: L03-RE037-IN-PHY-001		

Contents

1.0	GENERAL	4
2.0	gas booster COMPRESSOR.....	5
2.1	Unit control panel	5
2.1.1	Hardware switches and lamps UCP	5
2.1.2	HMI switches and indications UCP	5
2.2	Local Pushbutton Station	6
2.2.1	Hardware switches and lamps LPS	6
3.0	COMPRESSOR CONTROLS.....	7
3.1	START-UP.....	7
3.2	SHUTDOWN.....	8
3.2.1	PLANNED SHUTDOWN.....	8
3.2.2	UNPLANNED SHUTDOWN.....	8
3.3	TIMERS	8
3.4	MOTOR CONTROL	9
3.5	COMMON ALARM AND COMMON TRIP	9
3.5.1	COMMON ALARM.....	9
3.5.2	COMMON TRIP.....	10
3.5.3	EMERGENCY STOP FUNCTIONS	10
3.5.4	ESD SIGNALS.....	10
3.6	DISPLAY CONTROL.....	11
3.7	COMPRESSOR OIL SYSTEM.....	11
3.8	LOADING / UNLOADING INLET VALVE REGULATION	11

Vendor	ABT 360 KT/Y PP PLANT	Contractor (DEC)	Owner
	Control Philosophy		
	Vendor's Doc. No.: 2 3 2 4 9 - 2 1		سراج گستران رجمال SERAJ GOSTARAN REJAL (سهامی خاص)
	PPEC Doc. No.: L03-RE037-IN-PHY-001	Rev.: 03	

1.0 GENERAL

This document describes the operating and control narrative of the gas booster compressor as described below.



One (1) gas horizontal booster compressor (PK6801), 2 stage piston motor driven. Outlet capacity 1100-1200 kg/h at 21 bar(g).

There are two different inlet gas compositions;

Component	Case 1 (%)	Case 2 (%)
Propylene	77.0	70.2
Propane	23.0	26.2
Ethylene	–	3.3
Ethane	–	0.3

Included is,

- One (1) Unit control panel (UCP) with control PLC, tag number UCP-PK6801-01
- One (1) Local Pushbutton Station (LPS), tag number LCP-PK6801-01
- One (1) Analog Junction Box (JB), tag number JIAP-PK6801-01.

<p>Vendor</p> 	<p style="text-align: center;">ABT 360 KT/Y PP PLANT</p> <p style="text-align: center;">Control Philosophy</p> <p>Vendor's Doc. No.: 23249-21</p> <p>PPEC Doc. No.: L03-RE037-IN-PHY-001</p>	<p>Contractor (DEC)</p>	<p>Owner</p>  <p style="text-align: center;">سراج گستران رجال SERAJ GOSTARAN REJAL (سهامی خاص)</p>
	<p>Rev.: 03</p>		

2.0 GAS BOOSTER COMPRESSOR

2.1 Unit control panel

The Unit control Panel is located in the control room (safe area) and connected to the compressor LPS and JB with multipair cables.

2.1.1 Hardware switches and lamps UCP

The following buttons and lamps are provided on the Unit Control Panel.

Main power switch (one for each power supply)

To switch of the main power supply to the package.

Hour meter (HM-PK6801-01)

Counts compressor running hours, six digits, non-resettable, to confirm maintenance times.

Compressor power on lamp (WHITE) (XL-PK6801-05)

To confirm that the power to the package is ON.

ESD button (HS-PK6801-05)

To shut down the package without following the controlled stop sequence.

2.1.2 HMI switches and indications UCP

The below is shown on the HMI;

P&ID



A simplification of the P&ID, with process values and indication of which transmitters have alarm and trip, which valves are open and closed etc.

HMI settings

Here you can make the general changes to the settings of the HMI, like brightness, HMI status, etc.

Alarm and trip list (with first up alarm)

A list with all the active alarm and trips, with time stamp as per time synchronization.

Vendor	ABT 360 KT/Y PP PLANT	Contractor (DEC)	Owner
	Control Philosophy		 سراج گستران رجمال SERAJ GOSTARAN REJAL (سهامی خاص)
	Vendor's Doc. No.: 23249-21		
	PPEC Doc. No.: L03-RE037-IN-PHY-001	Rev.: 03	

2.2 Local Pushbutton Station

The Local Control Panel is located on the compressor package (hazardous area) and connected to the UCP with multipair cable.

2.2.1 Hardware switches and lamps LPS

The following buttons and lamps are provided on the compressor control panel.

Common alarm lamp (AMBER) (XL-PK6801-01)

Will blink at unacknowledged alarm(s), steady at acknowledged alarm(s).

Common trip lamp (RED) (XL-PK6801-02)

Will blink at unacknowledged trip(s), steady when at acknowledged trip(s).

Compressor Operational Lamp (GREEN) (XL-PK6801-03)

ON when compressor is ready to start and is OFF at failure.

Compressor Running Lamp (GREEN) (XL-PK6801-04)

ON when compressor is running either loading - unloading or cooling down.

Common Lamp test button (HS-PK6801-04)

To test if alarm, trip, operational and running lamps are glowing.

Compressor start button (HS-PK6801-01)

To start the package, via PLC controlled sequence.

Compressor stop button (HS-PK6801-02)



To stop the compressor, via PLC controlled sequence.

Local / OFF / Remote select switch (SW-PK6801-01)

To switch between start from LPS (local) or UCP and DCS (remote). Selection can be changed without the compressor stopping.

ESD button (HS-PK6801-03)

To shut down the package without following the controlled stop sequence.

<p>Vendor</p> 	<p style="text-align: center;">ABT 360 KT/Y PP PLANT</p> <hr/> <p style="text-align: center;">Control Philosophy</p> <hr/> <p>Vendor's Doc. No.: 23249-21</p> <hr/> <p>PPEC Doc. No.: L03-RE037-IN-PHY-001</p>	<p>Contractor (DEC)</p>	<p>Owner</p>  <p style="text-align: center;">سراج گستاران رجال SERAJ GOSTARAN REJAL (سهامی خاص)</p>
	<p>Rev.: 03</p>		

3.0 COMPRESSOR CONTROLS

The start and stop logic for the compressor will be described in this block, including all timers and the starting and stopping of the motor.

In case of emergency the compressor can always be shut down by pressing the ESD BUTTON on the LPS (HS-PK6801-03) or on the UCP (HS-PK6801-05).

3.1 START-UP



The compressor can be started locally by pressing start button (HS-PK-6801-01) and receiving 'Compressor start' signal (HS-PK6801-01) from LPS. Or compressor can be started by receiving remote start signal from DCS via hardwire signal XA-PK6803-05.

To start the operation, the following start conditions must first be met (ready to start):

- No trips and no ESD, 'compressor operational' lamp (XL-PK6801-03) is on.
- Minimum run timer is active (see section 3.3 TIMERS on page 8).
- Start-up delay timer is not active (see section 3.3 TIMERS on page 8).
- Motor is available, which is not running (XA-PK6803-01) and not fault (XA-PK6803-02) Signal from MCC.

After the above start conditions are met, the start button on the compressor LPS is pressed or the remote start signal is received from UCP/DCS. Then the following functions will be enabled:

- The start-up delay timer is activated. (see section 3.3 TIMERS on page 8)
- After start, the 'compressor running' lamp (XL-PK6801-04) will turn on.
- After the start up delay the compressor goes to load. The capacity is controlled with a bypass provided by others.
- Compressor keeps running in LOAD until stop command is given. When in UNLOAD and minimum run timer (see section 3.3 TIMERS on page 8) is not active compressor will shut down.

Vendor 	ABT 360 KT/Y PP PLANT Control Philosophy Vendor's Doc. No.: 23249-21 PPEC Doc. No.: L03-RE037-IN-PHY-001 Rev.: 03	Contractor (DEC)	Owner  سراج گستران رجال SERAJ GOSTARAN REJAL (سهامی خاص)
---	--	------------------	---

3.2 SHUTDOWN

The compressor can have two shut down situations:

1. Planned shutdown.
2. Unplanned shutdown

3.2.1 PLANNED SHUTDOWN

To initiate planned shutdown the 'compressor stop' button (HS-PK6801-02) on LPS needs to be pushed to receive signal HS-PK6801-02 or 'compressor stop' signal from DCS via hardwire signal XA-PK6803-06 need to be received.

The below stop conditions have to be met:

- Minimum run timer is not active (see section 3.3 TIMERS on page 8).
- Cool down timer is not active (see section 3.3 TIMERS on page 8).

When all conditions have been met the compressor will shut down.

3.2.2 UNPLANNED SHUTDOWN

In case of a trip or emergency stop button pressure, the compressor motor will shut down immediately, common trip lamp (XL-PK6801-02) will go on, MINIMUM RUN TIMER and COOL DOWN TIMER are cancelled.

After any shutdown, a RESTART DELAY TIMER (see section 3.3 TIMERS on page 8) will be active. This is to prevent the motor from starting directly after a stop. The compressor needs to get to a complete standstill before starting it again. Please be aware that the alarm reset button (HMI) needs to be pressed to restart the compressor after any trip or ESD.

3.3 TIMERS

MINIMUM RUN TIMER:

- Minimum running time after initial start
- To protect the motor by preventing more than 3 starts per hour
- Duration: 30 minutes

RESTART DELAY TIMER:



- To let the compressor come to a complete stop
- Prevents the compressor from restarting until a certain time after stopping
- Duration: 1 minute for normal shutdown.

COOL DOWN TIMER:

- Keeps the compressor running unloaded for a certain time after stop
- To equalize pressure to inlet pressure and cool down of the compressor
- Duration: 3 minutes

START-UP DELAY TIMER:

- To prevent high start current until full speed of the motor, and low oil pressure trip during start-up.
- Duration: 20 seconds

Vendor 	ABT 360 KT/Y PP PLANT Control Philosophy Vendor's Doc. No.: 23249-21 PPEC Doc. No.: L03-RE037-IN-PHY-001 Rev.: 03	Contractor (DEC)	Owner  سراج گستران رجال SERAJ GOSTARAN REJAL (سهامی خاص)
---	--	------------------	---

3.4 MOTOR CONTROL

There is one (1) motor which require starting, this is the main motor. The motor is protected in MCC (client scope).

The main motor has the following sequence for starting / stopping:

- The MCC is not sending 'main motor fault' (XA-PK6803-02) and not sending 'main motor running' (XA-PK6803-01), which means motor is available and ready to start.
- The UCP (PLC) is sending signal 'main motor start' (XA-PK6803-03) to the MCC, which is starting the motor.
- Within 2 second the 'main motor running' signal (XA-PK6803-01) is received by the UCP from the MCC, If not, the PLC in DCS will generate a trip.
- When stopping the motor, by trip or normal, the 'main motor stop' signal (XA-PK6803-04) is sent from the UCP to the MCC to stop the motor.

When the compressor is started, main motor is started. When the compressor is stopped or tripped the main motor will stop. When the main motor is tripped the complete compressor package is tripped.



3.5 COMMON ALARM AND COMMON TRIP

3.5.1 COMMON ALARM

All alarms will be collected here and put into one common alarm block, if this common alarm is active the COMMON alarm LAMP will blink, this means that a new alarm is present, and the cause should be investigated.

The common alarm is transmitted also to DCS via MODBUS TCP/IP feedback signal. The package will continue to run with the alarm; however, the cause of the alarm should be investigated by the operator.

If the COMMON alarm LAMP blinks it needs to be acknowledged by the ACKNOWLEDGE BUTTON (HMI) and necessary maintenance must be done according to the maintenance MANUAL. If ACKNOWLEDGE BUTTON (HMI) is pressed the COMMON ALARM LAMP will be on steady. If maintenance has been carried out the RESET BUTTON (HMI) can be pressed, COMMON ALARM LAMP should turn off, unless an alarm is still present, the COMMON ALARM LAMP will start blinking again.

Vendor 	ABT 360 KT/Y PP PLANT		Contractor (DEC)	Owner  سراج گستاران رجمال SERAJ GOSTARAN REJAL (سهامی خاص)
	Control Philosophy			
	Vendor's Doc. No.: 2 3 2 4 9 - 2 1	Rev.: 03		
PPEC Doc. No.: L03-RE037-IN-PHY-001				

3.5.2 COMMON TRIP

All trips will be collected here and put into one common trip block, if this common trip is active the COMMON TRIP LAMP will blink, this means that a new trip is present, and the cause should be investigated.

The common trip is transmitted also to DCS via MODBUS TCP/IP feedback signal. The package will stop immediately as described in 3.2.2 UNPLANNED SHUTDOWN on page 8.

If the COMMON TRIP LAMP blinks it needs to be acknowledged by the ACKNOWLEDGE BUTTON (HMI) and necessary maintenance must be done according to the maintenance MANUAL. If ACKNOWLEDGE BUTTON (HMI) is pressed the COMMON TRIP LAMP will be on steady. If maintenance has been carried out the RESET BUTTON (HMI) can be pressed, COMMON TRIP LAMP should turn off, unless a trip is still present, the COMMON TRIP LAMP will start blinking again. In case of a trip the package will stop immediately, all timers (MINIMUM RUN and COOLDOWN) will be cancelled.

NOTE

Cable fractures and over range/sensor failure of transmitters will be separately programmed as a trip, but not shown on display.

3.5.3 EMERGENCY STOP FUNCTIONS



An emergency stop can be activated by pressing the local ESD BUTTON (HS-PK6801-03) on compressor LPS or by pressing the remote ESD BUTTON (HS-PK6801-05) on the UCP.

An Emergency stop signal activates an ESD relay inside the panel, the ESD relay sends a trip signal to the PLC, causing the compressor to trip. Separately the ESD relay also disconnects power to all the solenoid valves as well as activating the motor shutdown signals, forcing the motor to stop.

3.5.4 ESD SIGNALS

Please find below all ESD signals:

Service	Source	Value 0	Value 1
ESD pushbutton (HS-PK6801-03)	LPS	Trip	Operational
ESD pushbutton (HS-PK6801-05)	UCP	Trip	Operational
ESD signal (ESD-PK6801-05 / 06)	ESD	Trip	Operational

Vendor 	ABT 360 KT/Y PP PLANT		Contractor (DEC)	Owner  سراج گستران رجال SERAJ GOSTARAN REJAL (سهامی خاص)
	Control Philosophy			
	Vendor's Doc. No.: 23249-21	Rev.: 03		
PPEC Doc. No.: L03-RE037-IN-PHY-001				

3.6 DISPLAY CONTROL

All signals that are coming from or going to the display are collected here. All signals are put in one block to be transferred to the display.

The following information will be available on the display as a minimum:

- Running status
- Alarms and trips
- Process values
- Duty/Stand-by

3.7 COMPRESSOR OIL SYSTEM

The compressor oil system consists of a crank driven rotary oil pump. As soon as compressor starts oil will be supplied. Normal oil pressure will be around 2 bar(g).

When compressor is started the oil pressure trip will be bypassed for 20 seconds (START-UP DELAY TIMER as mentioned in chapter 3.3 TIMERS on page 8).

Oil level can be checked by reading the level gauge on the oil sump. The system is fully mechanical.

The compressor will trip when the oil pressure drops below 1,5 bar(g).

3.8 LOADING / UNLOADING INLET VALVE REGULATION

Loading / unloading of the compressor is done by energizing and de-energizing the load / unload solenoid valve (XY-PK6801-01) between the stages of the compressor. After start up relay has become active the solenoid valve (XY-PK6801-01) is energized the compressor suction valve is pressurized, which causes the suction valve to open and compressor to go into load. If the solenoid valve (XY-PK6801-01) is de-energized the suction valve will be de-pressurized, which causes the suction valve to close and the compressor to go to unload.

The capacity control is done by the bypass over the compressor (not in Airpack scope) control is 0-100%.

The compressor control is done by others. The compressor is in unload during start-up and fails to not damage the compressor.

When the compressor is running in UNLOAD and the minimum run timer is not active the compressor will shut down and cool down timer is active.